

令和4年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	2.7	6.5	3.7	7.69	43.8	45.5	100	6.9	0.16	0.03	
2	晴	4.3	6.6	3.5	7.68	—	—	—	—	—	—	
3	曇	5.2	6.5	3.6	7.65	—	—	—	—	—	—	
4	晴	4.1	6.4	3.6	7.66	—	—	—	—	—	—	
5	晴	4.0	5.8	3.5	7.50	—	—	—	—	—	—	
6	晴	4.2	5.6	3.0	7.35	—	—	—	—	—	—	
7	晴	1.6	6.4	2.6	7.70	—	—	—	—	—	—	
8	曇	4.9	6.6	2.7	7.69	—	—	—	—	—	—	
9	晴	5.3	6.6	2.7	7.70	—	—	—	—	—	—	
10	雨	4.8	7.0	3.0	7.69	—	—	—	—	—	—	
11	晴	3.1	6.1	2.8	7.75	—	—	—	—	—	—	
12	晴	9.0	6.2	2.6	7.45	—	—	—	—	—	—	
13	曇	10.0	6.5	2.4	7.52	—	—	—	—	—	—	
14	曇	6.0	7.3	2.4	7.65	—	—	—	—	—	—	
15	晴	6.1	6.3	2.5	7.71	43.0	48.6	74	7.0	0.11	<0.02	
16	晴	4.1	7.6	2.2	7.70	—	—	—	—	—	—	
17	晴	0.8	7.4	2.8	7.69	—	—	—	—	—	—	
18	晴	1.6	7.3	3.4	7.70	—	—	—	—	—	—	
19	曇	10.0	10.1	4.4	7.23	—	—	—	—	—	—	
20	晴	10.0	6.8	4.2	7.42	—	—	—	—	—	—	
21	晴	1.7	7.3	4.0	7.69	—	—	—	—	—	—	
22	晴	2.0	7.3	3.7	7.67	—	—	—	—	—	—	
23	晴	6.0	6.0	4.1	7.51	—	—	—	—	—	—	
24	晴	2.4	7.0	3.4	7.69	—	—	—	—	—	—	
25	晴	4.0	7.2	3.0	7.70	—	—	—	—	—	—	
26	晴	9.0	6.1	3.1	7.59	—	—	—	—	—	—	
27	晴	10.0	6.3	3.1	7.53	—	—	—	—	—	—	
28	晴	7.3	7.6	2.3	7.68	—	—	—	—	—	—	
平均		5.2	6.8	3.2	7.61	43.4	47.0	87	7.0	0.14	<0.02	
最高		10.0	10.1	4.4	7.75	43.8	48.6	100	7.0	0.16	0.03	
最低		0.8	5.6	2.2	7.23	43.0	45.5	74	6.9	0.11	<0.02	

令和4年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	2.7	8.6	0.4	7.41	37.4	46.5	98	11.2	<0.03	<0.02	
2	晴	4.3	8.7	0.4	7.40	—	—	—	—	—	—	
3	曇	5.2	8.6	0.3	7.35	—	—	—	—	—	—	
4	晴	4.1	8.5	0.3	7.41	—	—	—	—	—	—	
5	晴	4.0	8.4	0.4	7.40	—	—	—	—	—	—	
6	晴	4.2	8.3	0.4	7.41	—	—	—	—	—	—	
7	晴	1.6	8.2	0.2	7.44	—	—	—	—	—	—	
8	曇	4.9	8.3	0.2	7.47	—	—	—	—	—	—	
9	晴	5.3	8.4	0.3	7.48	—	—	—	—	—	—	
10	雨	4.8	8.6	0.3	7.43	—	—	—	—	—	—	
11	晴	3.1	8.6	0.3	7.49	—	—	—	—	—	—	
12	晴	9.0	8.8	0.4	7.44	—	—	—	—	—	—	
13	曇	10.0	8.9	0.3	7.46	—	—	—	—	—	—	
14	曇	6.0	9.0	0.3	7.48	—	—	—	—	—	—	
15	晴	6.1	8.8	0.3	7.45	39.2	49.4	86	11.2	<0.03	<0.02	
16	晴	4.1	9.0	0.2	7.48	—	—	—	—	—	—	
17	晴	0.8	8.7	0.3	7.51	—	—	—	—	—	—	
18	晴	1.6	8.6	0.4	7.45	—	—	—	—	—	—	
19	曇	10.0	8.6	0.2	7.42	—	—	—	—	—	—	
20	晴	10.0	9.0	0.3	7.44	—	—	—	—	—	—	
21	晴	1.7	8.8	0.4	7.49	—	—	—	—	—	—	
22	晴	2.0	8.7	0.4	7.48	—	—	—	—	—	—	
23	晴	6.0	8.5	0.4	7.47	—	—	—	—	—	—	
24	晴	2.4	8.4	0.3	7.50	—	—	—	—	—	—	
25	晴	4.0	8.5	0.4	7.45	—	—	—	—	—	—	
26	晴	9.0	8.6	0.4	7.47	—	—	—	—	—	—	
27	晴	10.0	8.8	0.4	7.49	—	—	—	—	—	—	
28	晴	7.3	9.0	0.3	7.47	—	—	—	—	—	—	
平均		5.2	8.6	0.3	7.45	38.3	48.0	92	11.2	<0.03	<0.02	
最高		10.0	9.0	0.4	7.51	39.2	49.4	98	11.2	<0.03	<0.02	
最低		0.8	8.2	0.2	7.35	37.4	46.5	86	11.2	<0.03	<0.02	