

令和4年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	8.6	7.9	2.2	7.64	44.7	54.5	100	9.0	0.17	0.02	
2	晴	9.2	8.0	4.6	7.58	—	—	—	—	—	—	
3	晴	8.8	8.1	2.7	7.65	—	—	—	—	—	—	
4	晴	6.8	8.2	2.6	7.66	—	—	—	—	—	—	
5	晴	13.5	7.3	2.7	7.66	—	—	—	—	—	—	
6	晴	8.0	7.2	2.4	7.60	—	—	—	—	—	—	
7	晴	6.1	8.1	2.7	7.75	—	—	—	—	—	—	
8	晴	8.2	8.3	2.2	7.76	—	—	—	—	—	—	
9	晴	8.0	8.5	2.0	7.73	—	—	—	—	—	—	
10	晴	8.1	8.6	2.3	7.74	—	—	—	—	—	—	
11	晴	9.5	8.6	2.0	7.75	—	—	—	—	—	—	
12	晴	16.0	8.0	2.8	7.56	—	—	—	—	—	—	
13	晴	18.0	8.4	2.9	7.59	—	—	—	—	—	—	
14	晴	15.1	10.1	3.0	7.68	—	—	—	—	—	—	
15	曇	17.3	10.6	2.4	7.66	43.5	51.6	110	8.9	0.12	<0.02	
16	晴	13.5	10.5	2.4	7.71	—	—	—	—	—	—	
17	晴	13.3	10.8	2.5	7.69	—	—	—	—	—	—	
18	曇	13.4	10.8	2.6	7.77	—	—	—	—	—	—	
19	晴	14.5	9.5	3.2	7.79	—	—	—	—	—	—	
20	晴	11.0	9.2	3.3	7.54	—	—	—	—	—	—	
21	曇	9.9	10.6	2.5	7.68	—	—	—	—	—	—	
22	雨	7.6	11.0	2.6	7.64	—	—	—	—	—	—	
23	曇	7.5	10.6	2.6	7.62	—	—	—	—	—	—	
24	晴	10.0	10.6	2.6	7.65	—	—	—	—	—	—	
25	晴	10.5	10.7	2.7	7.63	—	—	—	—	—	—	
26	曇	15.0	10.0	3.7	7.76	—	—	—	—	—	—	
27	晴	17.0	10.5	4.3	8.08	—	—	—	—	—	—	
28	晴	14.8	11.7	6.9	7.58	—	—	—	—	—	—	
29	曇	13.9	11.8	3.2	7.59	—	—	—	—	—	—	
30	晴	15.4	11.8	3.4	7.56	—	—	—	—	—	—	
31	晴	16.8	12.0	3.2	7.58	—	—	—	—	—	—	
平均		11.8	9.6	2.9	7.67	44.1	53.0	105	9.0	0.14	<0.02	
最高		18.0	12.0	6.9	8.08	44.7	54.5	110	9.0	0.17	0.02	
最低		6.1	7.2	2.0	7.54	43.5	51.6	100	8.9	0.12	<0.02	

令和4年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	8.6	9.2	0.3	7.43	39.4	51.8	89	12.2	0.05	<0.02	
2	晴	9.2	9.1	0.4	7.37	—	—	—	—	—	—	
3	晴	8.8	9.3	0.2	7.42	—	—	—	—	—	—	
4	晴	6.8	9.5	0.4	7.42	—	—	—	—	—	—	
5	晴	13.5	9.5	0.4	7.39	—	—	—	—	—	—	
6	晴	8.0	9.6	0.4	7.45	—	—	—	—	—	—	
7	晴	6.1	9.5	0.5	7.59	—	—	—	—	—	—	
8	晴	8.2	9.5	0.3	7.55	—	—	—	—	—	—	
9	晴	8.0	9.7	0.2	7.50	—	—	—	—	—	—	
10	晴	8.1	9.6	0.4	7.54	—	—	—	—	—	—	
11	晴	9.5	9.9	0.4	7.54	—	—	—	—	—	—	
12	晴	16.0	10.2	0.4	7.45	—	—	—	—	—	—	
13	晴	18.0	10.5	0.5	7.59	—	—	—	—	—	—	
14	晴	15.1	11.1	0.5	7.45	—	—	—	—	—	—	
15	曇	17.3	11.8	0.4	7.45	39.9	51.7	94	13.0	<0.03	<0.02	
16	晴	13.5	11.8	0.4	7.43	—	—	—	—	—	—	
17	晴	13.3	12.1	0.6	7.46	—	—	—	—	—	—	
18	曇	13.4	12.2	0.4	7.46	—	—	—	—	—	—	
19	晴	14.5	12.0	0.3	7.49	—	—	—	—	—	—	
20	晴	11.0	11.8	0.4	7.58	—	—	—	—	—	—	
21	曇	9.9	11.7	0.5	7.55	—	—	—	—	—	—	
22	雨	7.6	11.9	0.5	7.54	—	—	—	—	—	—	
23	曇	7.5	11.6	0.4	7.45	—	—	—	—	—	—	
24	晴	10.0	11.7	0.4	7.50	—	—	—	—	—	—	
25	晴	10.5	11.8	0.3	7.55	—	—	—	—	—	—	
26	曇	15.0	12.2	0.3	7.50	—	—	—	—	—	—	
27	晴	17.0	12.6	0.7	7.49	—	—	—	—	—	—	
28	晴	14.8	12.6	0.4	7.50	—	—	—	—	—	—	
29	曇	13.9	12.8	0.4	7.45	—	—	—	—	—	—	
30	晴	15.4	12.9	0.4	7.44	—	—	—	—	—	—	
31	晴	16.8	13.3	0.5	7.48	—	—	—	—	—	—	
平均		11.8	11.1	0.4	7.48	39.6	51.8	92	12.6	<0.03	<0.02	
最高		18.0	13.3	0.7	7.59	39.9	51.8	94	13.0	0.05	<0.02	
最低		6.1	9.1	0.2	7.37	39.4	51.7	89	12.2	<0.03	<0.02	