

令和4年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	16.8	18.3	1.8	7.69	40.4	40.6	74	3.6	0.07	<0.02	
2	晴	15.5	18.3	1.2	7.70	—	—	—	—	—	—	
3	晴	15.3	18.2	1.4	7.70	—	—	—	—	—	—	
4	晴	15.4	18.0	1.4	7.63	—	—	—	—	—	—	
5	晴	19.5	16.6	3.1	7.74	—	—	—	—	—	—	
6	晴	18.0	16.3	2.4	7.75	—	—	—	—	—	—	
7	晴	13.0	17.4	2.5	7.66	—	—	—	—	—	—	
8	晴	15.5	17.3	1.0	7.69	—	—	—	—	—	—	
9	晴	13.6	17.2	1.1	7.70	—	—	—	—	—	—	
10	晴	13.0	17.0	1.2	7.71	—	—	—	—	—	—	
11	晴	13.5	16.9	6.1	7.63	—	—	—	—	—	—	
12	晴	21.0	15.6	6.7	7.64	—	—	—	—	—	—	
13	曇	21.0	15.8	4.8	7.71	—	—	—	—	—	—	
14	曇	13.6	16.9	3.3	7.73	—	—	—	—	—	—	
15	晴	13.2	16.7	2.1	7.65	41.2	41.3	72	4.2	0.14	<0.02	
16	晴	11.6	16.5	2.3	7.68	—	—	—	—	—	—	
17	晴	12.7	16.2	2.0	7.68	—	—	—	—	—	—	
18	晴	12.0	16.1	1.8	7.70	—	—	—	—	—	—	
19	晴	15.0	14.1	2.9	7.67	—	—	—	—	—	—	
20	曇	15.5	14.7	2.7	7.60	—	—	—	—	—	—	
21	雨	13.9	15.7	1.7	7.71	—	—	—	—	—	—	
22	晴	13.8	15.7	1.5	7.68	—	—	—	—	—	—	
23	雨	14.0	15.9	1.4	7.68	—	—	—	—	—	—	
24	晴	15.3	15.7	1.5	7.71	—	—	—	—	—	—	
25	晴	12.5	15.6	1.5	7.71	—	—	—	—	—	—	
26	曇	14.5	14.5	2.5	7.59	—	—	—	—	—	—	
27	晴	17.0	14.4	2.4	7.66	—	—	—	—	—	—	
28	曇	15.6	15.4	1.4	7.73	—	—	—	—	—	—	
29	曇	18.8	15.5	1.3	7.69	—	—	—	—	—	—	
30	晴	18.1	15.7	2.2	7.66	—	—	—	—	—	—	
平均		15.3	16.3	2.3	7.68	40.8	41.0	73	3.9	0.10	<0.02	
最高		21.0	18.3	6.7	7.75	41.2	41.3	74	4.2	0.14	<0.02	
最低		11.6	14.1	1.0	7.59	40.4	40.6	72	3.6	0.07	<0.02	

令和4年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	16.8	19.4	0.3	7.51	36.8	40.5	66	6.8	<0.03	<0.02	
2	晴	15.5	19.2	0.3	7.51	—	—	—	—	—	—	
3	晴	15.3	19.3	0.4	7.51	—	—	—	—	—	—	
4	晴	15.4	19.3	0.3	7.38	—	—	—	—	—	—	
5	晴	19.5	19.0	0.4	7.48	—	—	—	—	—	—	
6	晴	18.0	18.8	0.5	7.49	—	—	—	—	—	—	
7	晴	13.0	18.6	0.2	7.50	—	—	—	—	—	—	
8	晴	15.5	18.6	0.2	7.52	—	—	—	—	—	—	
9	晴	13.6	18.4	0.2	7.48	—	—	—	—	—	—	
10	晴	13.0	18.3	0.2	7.47	—	—	—	—	—	—	
11	晴	13.5	18.2	0.3	7.47	—	—	—	—	—	—	
12	晴	21.0	18.2	0.4	7.44	—	—	—	—	—	—	
13	曇	21.0	18.3	0.2	7.47	—	—	—	—	—	—	
14	曇	13.6	18.2	0.3	7.49	—	—	—	—	—	—	
15	晴	13.2	18.0	0.1	7.42	37.4	41.2	66	7.6	0.03	<0.02	
16	晴	11.6	17.9	0.2	7.45	—	—	—	—	—	—	
17	晴	12.7	17.5	0.2	7.48	—	—	—	—	—	—	
18	晴	12.0	17.4	0.2	7.46	—	—	—	—	—	—	
19	晴	15.0	17.2	0.3	7.49	—	—	—	—	—	—	
20	曇	15.5	17.2	0.2	7.47	—	—	—	—	—	—	
21	雨	13.9	16.9	0.2	7.50	—	—	—	—	—	—	
22	晴	13.8	17.1	0.2	7.53	—	—	—	—	—	—	
23	雨	14.0	17.2	0.2	7.48	—	—	—	—	—	—	
24	晴	15.3	17.0	0.1	7.47	—	—	—	—	—	—	
25	晴	12.5	16.9	0.3	7.44	—	—	—	—	—	—	
26	曇	14.5	16.9	0.4	7.51	—	—	—	—	—	—	
27	晴	17.0	16.9	0.2	7.50	—	—	—	—	—	—	
28	曇	15.6	16.9	0.2	7.49	—	—	—	—	—	—	
29	曇	18.8	16.9	0.2	7.49	—	—	—	—	—	—	
30	晴	18.1	17.0	0.3	7.48	—	—	—	—	—	—	
平均		15.3	17.9	0.3	7.48	37.1	40.8	66	7.2	<0.03	<0.02	
最高		21.0	19.4	0.5	7.53	37.4	41.2	66	7.6	0.03	<0.02	
最低		11.6	16.9	0.1	7.38	36.8	40.5	66	6.8	<0.03	<0.02	