

令和5年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	3.3	7.7	2.5	7.62	—	—	—	—	—	—	
2	曇	6.0	7.9	3.3	7.61	—	—	—	—	—	—	
3	曇	6.9	8.1	3.4	7.58	—	—	—	—	—	—	
4	晴	8.0	7.0	8.4	7.54	—	—	—	—	—	—	
5	晴	10.0	7.6	6.0	7.49	—	—	—	—	—	—	
6	晴	3.4	8.2	3.4	7.53	—	—	—	—	—	—	
7	曇	8.4	8.5	3.0	7.55	43.0	48.3	61	6.3	0.21	0.05	
8	晴	8.2	8.5	3.3	7.63	—	—	—	—	—	—	
9	晴	5.1	8.2	3.2	7.54	—	—	—	—	—	—	
10	雨	7.2	8.7	3.8	7.58	—	—	—	—	—	—	
11	晴	11.0	7.3	4.9	7.68	—	—	—	—	—	—	
12	曇	12.0	7.7	5.3	7.78	—	—	—	—	—	—	
13	雨	10.7	9.2	4.5	7.59	—	—	—	—	—	—	
14	晴	4.6	8.9	6.4	7.52	—	—	—	—	—	—	
15	曇	2.7	8.5	5.6	7.52	—	—	—	—	—	—	
16	曇	3.5	8.5	5.4	7.58	—	—	—	—	—	—	
17	晴	1.4	8.3	5.5	7.51	—	—	—	—	—	—	
18	晴	14.0	7.2	6.0	7.28	—	—	—	—	—	—	
19	雨	6.0	8.1	5.8	7.30	—	—	—	—	—	—	
20	晴	9.4	9.0	5.6	7.61	—	—	—	—	—	—	
21	晴	2.7	8.9	5.0	7.56	43.1	50.6	97	6.7	0.24	0.08	
22	晴	3.5	8.8	5.8	7.60	—	—	—	—	—	—	
23	曇	7.1	9.0	5.0	7.58	—	—	—	—	—	—	
24	曇	8.3	8.9	4.2	7.59	—	—	—	—	—	—	
25	晴	9.5	7.9	4.0	7.62	—	—	—	—	—	—	
26	晴	8.5	7.3	3.3	7.65	—	—	—	—	—	—	
27	晴	5.0	8.9	3.6	7.50	—	—	—	—	—	—	
28	晴	9.1	8.9	4.0	7.61	—	—	—	—	—	—	
平均		7.0	8.3	4.6	7.56	43.0	49.4	79	6.5	0.22	0.06	
最高		14.0	9.2	8.4	7.78	43.1	50.6	97	6.7	0.24	0.08	
最低		1.4	7.0	2.5	7.28	43.0	48.3	61	6.3	0.21	0.05	

令和5年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	3.3	8.7	0.3	7.47	—	—	—	—	—	—	
2	曇	6.0	9.1	0.5	7.48	—	—	—	—	—	—	
3	曇	6.9	9.0	0.3	7.40	—	—	—	—	—	—	
4	晴	8.0	9.1	0.4	7.42	—	—	—	—	—	—	
5	晴	10.0	9.1	0.3	7.50	—	—	—	—	—	—	
6	晴	3.4	8.7	0.2	7.41	—	—	—	—	—	—	
7	曇	8.4	9.4	0.3	7.44	40.5	48.1	67	8.7	0.03	<0.02	
8	晴	8.2	9.7	0.3	7.44	—	—	—	—	—	—	
9	晴	5.1	9.4	0.2	7.40	—	—	—	—	—	—	
10	雨	7.2	9.6	<0.1	7.43	—	—	—	—	—	—	
11	晴	11.0	9.5	0.2	7.63	—	—	—	—	—	—	
12	曇	12.0	9.7	0.3	7.44	—	—	—	—	—	—	
13	雨	10.7	9.9	0.2	7.46	—	—	—	—	—	—	
14	晴	4.6	9.8	0.2	7.41	—	—	—	—	—	—	
15	曇	2.7	9.5	0.2	7.38	—	—	—	—	—	—	
16	曇	3.5	9.4	0.2	7.40	—	—	—	—	—	—	
17	晴	1.4	9.3	0.1	7.36	—	—	—	—	—	—	
18	晴	14.0	9.6	0.3	7.39	—	—	—	—	—	—	
19	雨	6.0	10.0	0.4	7.42	—	—	—	—	—	—	
20	晴	9.4	9.9	0.2	7.48	—	—	—	—	—	—	
21	晴	2.7	9.8	0.2	7.44	40.5	51.5	94	9.9	<0.03	<0.02	
22	晴	3.5	9.5	0.1	7.46	—	—	—	—	—	—	
23	曇	7.1	9.9	0.1	7.43	—	—	—	—	—	—	
24	曇	8.3	9.9	0.1	7.44	—	—	—	—	—	—	
25	晴	9.5	9.9	<0.1	7.46	—	—	—	—	—	—	
26	晴	8.5	9.7	0.4	7.50	—	—	—	—	—	—	
27	晴	5.0	9.7	0.2	7.36	—	—	—	—	—	—	
28	晴	9.1	9.9	0.2	7.48	—	—	—	—	—	—	
平均		7.0	9.5	0.2	7.44	40.5	49.8	80	9.3	<0.03	<0.02	
最高		14.0	10.0	0.5	7.63	40.5	51.5	94	9.9	0.03	<0.02	
最低		1.4	8.7	<0.1	7.36	40.5	48.1	67	8.7	<0.03	<0.02	