

令和5年5月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	16.3	15.8	12.1	7.58	—	—	—	—	—	—	
2	晴	15.8	15.9	7.8	7.55	—	—	—	—	—	—	
3	晴	18.7	16.0	6.2	7.57	—	—	—	—	—	—	
4	晴	19.5	16.3	6.2	7.61	—	—	—	—	—	—	
5	晴	19.1	16.7	6.8	7.59	—	—	—	—	—	—	
6	曇	22.0	15.7	9.2	7.65	—	—	—	—	—	—	
7	雨	19.5	15.9	11.0	7.87	—	—	—	—	—	—	
8	晴	18.1	17.3	154.1	7.47	—	—	—	—	—	—	
9	晴	16.8	17.0	71.6	7.53	29.9	32.0	122	2.8	3.60	0.12	
10	晴	17.2	16.9	161.2	7.51	—	—	—	—	—	—	
11	晴	19.8	17.1	182.0	7.52	—	—	—	—	—	—	
12	晴	19.3	17.0	154.0	7.58	—	—	—	—	—	—	
13	雨	16.5	15.5	129.0	7.72	—	—	—	—	—	—	
14	雨	14.5	15.4	132.9	7.76	—	—	—	—	—	—	
15	曇	17.4	16.6	76.2	7.63	—	—	—	—	—	—	
16	晴	18.4	16.9	59.2	7.60	—	—	—	—	—	—	
17	晴	22.6	17.7	58.3	7.62	—	—	—	—	—	—	
18	晴	23.6	17.8	42.2	7.62	—	—	—	—	—	—	
19	雨	21.3	18.0	43.0	7.58	—	—	—	—	—	—	
20	曇	24.0	16.5	38.0	7.79	—	—	—	—	—	—	
21	晴	24.0	17.2	27.1	7.77	—	—	—	—	—	—	
22	晴	23.8	18.5	20.7	7.55	32.7	33.8	41	3.4	1.10	0.05	
23	雨	18.8	18.6	19.4	7.54	—	—	—	—	—	—	
24	晴	19.3	18.1	16.6	7.56	—	—	—	—	—	—	
25	曇	20.1	18.3	16.3	7.54	—	—	—	—	—	—	
26	晴	21.2	18.3	14.8	7.57	—	—	—	—	—	—	
27	晴	24.0	17.8	13.1	7.68	—	—	—	—	—	—	
28	晴	23.0	18.1	11.9	7.60	—	—	—	—	—	—	
29	雨	24.8	19.1	11.7	7.57	—	—	—	—	—	—	
30	雨	20.7	19.0	10.8	7.60	—	—	—	—	—	—	
31	雨	19.6	18.8	10.8	7.57	—	—	—	—	—	—	
平均		20.0	17.2	49.5	7.61	31.3	32.9	82	3.1	2.35	0.08	
最高		24.8	19.1	182.0	7.87	32.7	33.8	122	3.4	3.60	0.12	
最低		14.5	15.4	6.2	7.47	29.9	32.0	41	2.8	1.10	0.05	

令和5年5月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	16.3	17.1	<0.1	7.34	—	—	—	—	—	—	
2	晴	15.8	17.2	<0.1	7.34	—	—	—	—	—	—	
3	晴	18.7	17.2	<0.1	7.32	—	—	—	—	—	—	
4	晴	19.5	17.5	<0.1	7.36	—	—	—	—	—	—	
5	晴	19.1	17.8	0.1	7.35	—	—	—	—	—	—	
6	曇	22.0	18.1	<0.1	7.32	—	—	—	—	—	—	
7	雨	19.5	18.2	0.1	7.34	—	—	—	—	—	—	
8	晴	18.1	18.3	0.2	7.33	—	—	—	—	—	—	
9	晴	16.8	18.2	<0.1	7.13	23.0	30.3	40	7.9	0.04	<0.02	
10	晴	17.2	18.1	0.4	7.09	—	—	—	—	—	—	
11	晴	19.8	18.1	0.4	7.10	—	—	—	—	—	—	
12	晴	19.3	18.2	0.4	7.19	—	—	—	—	—	—	
13	雨	16.5	18.2	0.5	7.22	—	—	—	—	—	—	
14	雨	14.5	17.9	0.4	7.26	—	—	—	—	—	—	
15	曇	17.4	17.7	0.1	7.36	—	—	—	—	—	—	
16	晴	18.4	17.9	0.3	7.33	—	—	—	—	—	—	
17	晴	22.6	18.4	0.4	7.32	—	—	—	—	—	—	
18	晴	23.6	18.6	0.4	7.28	—	—	—	—	—	—	
19	雨	21.3	19.0	0.2	7.28	—	—	—	—	—	—	
20	曇	24.0	18.8	0.3	7.30	—	—	—	—	—	—	
21	晴	24.0	19.0	0.2	7.32	—	—	—	—	—	—	
22	晴	23.8	19.3	0.4	7.30	29.0	34.4	27	6.9	0.03	<0.02	
23	雨	18.8	19.6	0.2	7.34	—	—	—	—	—	—	
24	晴	19.3	19.1	0.3	7.29	—	—	—	—	—	—	
25	曇	20.1	19.2	0.3	7.33	—	—	—	—	—	—	
26	晴	21.2	19.1	0.2	7.36	—	—	—	—	—	—	
27	晴	24.0	20.0	0.4	7.44	—	—	—	—	—	—	
28	晴	23.0	19.6	0.3	7.38	—	—	—	—	—	—	
29	雨	24.8	20.0	<0.1	7.41	—	—	—	—	—	—	
30	雨	20.7	20.1	0.2	7.42	—	—	—	—	—	—	
31	雨	19.6	19.8	0.2	7.38	—	—	—	—	—	—	
平均		20.0	18.6	0.2	7.31	26.0	32.4	34	7.4	0.04	<0.02	
最高		24.8	20.1	0.5	7.44	29.0	34.4	40	7.9	0.04	<0.02	
最低		14.5	17.1	<0.1	7.09	23.0	30.3	27	6.9	0.03	<0.02	