

令和5年7月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	雨	23.5	21.0	50.8	7.78	—	—	—	—	—	—	
2	晴	28.0	21.3	31.6	7.80	—	—	—	—	—	—	
3	晴	26.4	22.3	46.7	7.66	—	—	—	—	—	—	
4	晴	27.1	22.3	64.9	7.63	34.7	36.5	124	2.7	3.50	0.09	
5	曇	25.3	22.3	86.0	7.67	—	—	—	—	—	—	
6	晴	25.1	22.3	82.0	7.67	—	—	—	—	—	—	
7	晴	28.6	21.5	80.4	7.74	—	—	—	—	—	—	
8	曇	27.0	22.0	75.3	7.65	—	—	—	—	—	—	
9	雨	26.5	21.7	68.3	7.69	—	—	—	—	—	—	
10	晴	28.3	23.0	41.0	7.68	—	—	—	—	—	—	
11	晴	28.8	23.2	33.5	7.64	—	—	—	—	—	—	
12	晴	30.0	23.3	29.0	7.65	—	—	—	—	—	—	
13	曇	27.4	23.4	25.0	7.66	—	—	—	—	—	—	
14	曇	28.5	23.3	28.1	7.67	—	—	—	—	—	—	
15	曇	27.0	22.8	35.2	7.73	—	—	—	—	—	—	
16	晴	30.0	22.8	32.7	7.69	—	—	—	—	—	—	
17	晴	28.1	23.6	45.8	7.68	—	—	—	—	—	—	
18	晴	29.3	23.8	46.8	7.64	34.3	36.6	101	2.4	2.30	0.07	
19	曇	29.0	24.0	41.9	7.63	—	—	—	—	—	—	
20	晴	29.1	24.0	30.5	7.65	—	—	—	—	—	—	
21	晴	28.0	24.1	27.3	7.66	—	—	—	—	—	—	
22	晴	31.0	23.3	28.3	7.69	—	—	—	—	—	—	
23	晴	30.0	23.5	24.9	7.66	—	—	—	—	—	—	
24	晴	28.1	24.7	18.0	7.63	—	—	—	—	—	—	
25	晴	28.5	24.9	15.4	7.66	—	—	—	—	—	—	
26	晴	29.6	25.1	13.4	7.68	—	—	—	—	—	—	
27	晴	30.1	25.5	12.9	7.65	—	—	—	—	—	—	
28	晴	30.1	25.6	8.9	7.68	—	—	—	—	—	—	
29	晴	32.0	24.6	13.9	7.69	—	—	—	—	—	—	
30	晴	33.1	25.0	11.0	7.63	—	—	—	—	—	—	
31	曇	30.8	26.1	6.4	7.63	—	—	—	—	—	—	
平均		28.5	23.4	37.3	7.67	34.5	36.6	112	2.6	2.90	0.08	
最高		33.1	26.1	86.0	7.80	34.7	36.6	124	2.7	3.50	0.09	
最低		23.5	21.0	6.4	7.63	34.3	36.5	101	2.4	2.30	0.07	

令和5年7月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	雨	23.5	22.8	0.3	7.49	—	—	—	—	—	—	
2	晴	28.0	23.0	0.2	7.51	—	—	—	—	—	—	
3	晴	26.4	23.4	0.2	7.44	—	—	—	—	—	—	
4	晴	27.1	23.5	0.3	7.39	31.1	36.3	66	7.5	<0.03	<0.02	
5	曇	25.3	23.4	0.4	7.39	—	—	—	—	—	—	
6	晴	25.1	23.3	0.3	7.36	—	—	—	—	—	—	
7	晴	28.6	23.6	0.3	7.40	—	—	—	—	—	—	
8	曇	27.0	23.9	0.3	7.40	—	—	—	—	—	—	
9	雨	26.5	24.0	0.3	7.42	—	—	—	—	—	—	
10	晴	28.3	24.0	0.2	7.49	—	—	—	—	—	—	
11	晴	28.8	24.3	0.3	7.41	—	—	—	—	—	—	
12	晴	30.0	24.5	0.2	7.43	—	—	—	—	—	—	
13	曇	27.4	24.5	0.3	7.46	—	—	—	—	—	—	
14	曇	28.5	24.3	0.3	7.47	—	—	—	—	—	—	
15	曇	27.0	24.5	0.7	7.46	—	—	—	—	—	—	
16	晴	30.0	24.7	0.2	7.48	—	—	—	—	—	—	
17	晴	28.1	25.0	0.2	7.52	—	—	—	—	—	—	
18	晴	29.3	25.0	0.2	7.47	31.0	36.0	66	6.3	<0.03	<0.02	
19	曇	29.0	25.0	0.2	7.39	—	—	—	—	—	—	
20	晴	29.1	25.0	0.2	7.44	—	—	—	—	—	—	
21	晴	28.0	25.0	0.3	7.44	—	—	—	—	—	—	
22	晴	31.0	25.1	0.4	7.45	—	—	—	—	—	—	
23	晴	30.0	25.3	0.3	7.46	—	—	—	—	—	—	
24	晴	28.1	25.5	0.2	7.49	—	—	—	—	—	—	
25	晴	28.5	25.7	0.2	7.46	—	—	—	—	—	—	
26	晴	29.6	25.9	0.2	7.51	—	—	—	—	—	—	
27	晴	30.1	26.1	0.2	7.48	—	—	—	—	—	—	
28	晴	30.1	26.3	0.4	7.54	—	—	—	—	—	—	
29	晴	32.0	26.4	0.2	7.51	—	—	—	—	—	—	
30	晴	33.1	26.6	0.2	7.51	—	—	—	—	—	—	
31	曇	30.8	26.8	0.2	7.54	—	—	—	—	—	—	
平均		28.5	24.7	0.3	7.46	31.0	36.2	66	6.9	<0.03	<0.02	
最高		33.1	26.8	0.7	7.54	31.1	36.3	66	7.5	<0.03	<0.02	
最低		23.5	22.8	0.2	7.36	31.0	36.0	66	6.3	<0.03	<0.02	