

令和5年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	29.3	26.1	5.8	7.62	37.8	41.8	61	4.3	0.30	<0.02	
2	晴	29.4	26.1	5.4	7.62	—	—	—	—	—	—	
3	晴	29.9	26.4	5.0	7.67	—	—	—	—	—	—	
4	晴	29.3	26.4	4.5	7.63	—	—	—	—	—	—	
5	晴	31.0	25.8	6.5	7.70	—	—	—	—	—	—	
6	晴	31.0	25.9	6.0	7.66	—	—	—	—	—	—	
7	曇	26.6	26.6	4.3	7.64	—	—	—	—	—	—	
8	晴	28.1	26.5	3.7	7.63	—	—	—	—	—	—	
9	雨	28.5	26.6	3.5	7.64	—	—	—	—	—	—	
10	晴	28.3	26.3	4.0	7.64	—	—	—	—	—	—	
11	晴	30.0	26.4	26.0	7.58	—	—	—	—	—	—	
12	晴	33.0	26.0	11.3	7.65	—	—	—	—	—	—	
13	晴	33.5	26.4	6.3	7.67	—	—	—	—	—	—	
14	曇	28.5	27.0	4.2	7.61	—	—	—	—	—	—	
15	雨	26.1	26.8	2.7	7.63	—	—	—	—	—	—	
16	雨	28.8	26.6	11.0	7.63	36.9	41.1	72	3.1	0.45	<0.02	
17	曇	29.8	25.9	73.6	7.58	—	—	—	—	—	—	
18	晴	28.8	25.5	72.9	7.48	—	—	—	—	—	—	
19	晴	31.5	24.7	53.5	7.48	—	—	—	—	—	—	
20	晴	33.0	24.8	31.9	7.52	—	—	—	—	—	—	
21	晴	30.6	26.1	27.7	7.52	—	—	—	—	—	—	
22	晴	30.9	26.3	14.6	7.53	—	—	—	—	—	—	
23	雨	28.1	26.4	11.3	7.55	—	—	—	—	—	—	
24	雨	25.0	26.4	8.6	7.56	—	—	—	—	—	—	
25	晴	28.0	25.5	150.4	7.50	—	—	—	—	—	—	
26	晴	33.0	24.3	47.2	7.44	—	—	—	—	—	—	
27	晴	31.0	24.6	25.3	7.51	—	—	—	—	—	—	
28	晴	28.8	25.8	22.2	7.55	—	—	—	—	—	—	
29	晴	28.1	25.9	12.2	7.57	—	—	—	—	—	—	
30	曇	29.4	26.1	8.9	7.60	—	—	—	—	—	—	
31	晴	28.8	26.1	7.2	7.61	—	—	—	—	—	—	
平均		29.6	26.0	21.9	7.59	37.4	41.4	66	3.7	0.38	<0.02	
最高		33.5	27.0	150.4	7.70	37.8	41.8	72	4.3	0.45	<0.02	
最低		25.0	24.3	2.7	7.44	36.9	41.1	61	3.1	0.30	<0.02	

令和5年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	29.3	27.0	0.1	7.49	36.3	40.1	53	6.5	0.03	<0.02	
2	晴	29.4	26.9	0.2	7.49	—	—	—	—	—	—	
3	晴	29.9	27.0	0.2	7.52	—	—	—	—	—	—	
4	晴	29.3	27.1	0.2	7.53	—	—	—	—	—	—	
5	晴	31.0	27.3	0.2	7.51	—	—	—	—	—	—	
6	晴	31.0	27.3	0.2	7.55	—	—	—	—	—	—	
7	曇	26.6	27.3	0.2	7.60	—	—	—	—	—	—	
8	晴	28.1	27.3	0.1	7.55	—	—	—	—	—	—	
9	雨	28.5	27.4	<0.1	7.62	—	—	—	—	—	—	
10	晴	28.3	27.2	0.2	7.57	—	—	—	—	—	—	
11	晴	30.0	27.3	<0.1	7.59	—	—	—	—	—	—	
12	晴	33.0	27.4	0.3	7.52	—	—	—	—	—	—	
13	晴	33.5	27.6	0.2	7.51	—	—	—	—	—	—	
14	曇	28.5	27.8	0.1	7.54	—	—	—	—	—	—	
15	雨	26.1	27.7	0.2	7.50	—	—	—	—	—	—	
16	雨	28.8	27.7	0.1	7.56	36.6	42.7	62	6.3	<0.03	<0.02	
17	曇	29.8	27.5	0.1	7.63	—	—	—	—	—	—	
18	晴	28.8	27.1	0.2	7.43	—	—	—	—	—	—	
19	晴	31.5	26.9	0.1	7.40	—	—	—	—	—	—	
20	晴	33.0	27.0	0.2	7.41	—	—	—	—	—	—	
21	晴	30.6	27.1	0.2	7.36	—	—	—	—	—	—	
22	晴	30.9	27.3	0.2	7.38	—	—	—	—	—	—	
23	雨	28.1	27.4	0.3	7.43	—	—	—	—	—	—	
24	雨	25.0	27.1	0.2	7.46	—	—	—	—	—	—	
25	晴	28.0	27.0	0.3	7.41	—	—	—	—	—	—	
26	晴	33.0	26.6	0.2	7.31	—	—	—	—	—	—	
27	晴	31.0	26.6	0.3	6.85	—	—	—	—	—	—	
28	晴	28.8	26.6	0.2	7.40	—	—	—	—	—	—	
29	晴	28.1	26.9	0.2	7.30	—	—	—	—	—	—	
30	曇	29.4	26.0	0.3	7.31	—	—	—	—	—	—	
31	晴	28.8	27.1	0.2	7.48	—	—	—	—	—	—	
平均		29.6	27.1	0.2	7.46	36.4	41.4	58	6.4	<0.03	<0.02	
最高		33.5	27.8	0.3	7.63	36.6	42.7	62	6.5	0.03	<0.02	
最低		25.0	26.0	<0.1	6.85	36.3	40.1	53	6.3	<0.03	<0.02	