

令和5年9月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	28.3	26.3	5.4	7.56	—	—	—	—	—	—	
2	晴	32.0	25.5	4.8	7.65	—	—	—	—	—	—	
3	晴	32.0	25.8	3.9	7.58	—	—	—	—	—	—	
4	曇	30.6	26.7	3.6	7.63	—	—	—	—	—	—	
5	晴	28.9	27.0	3.0	7.65	39.3	42.0	66	4.0	0.17	<0.02	
6	雨	24.7	26.8	26.5	7.65	—	—	—	—	—	—	
7	曇	25.7	26.3	3.3	7.63	—	—	—	—	—	—	
8	曇	23.1	25.9	3.8	7.63	—	—	—	—	—	—	
9	晴	27.5	25.0	3.1	7.62	—	—	—	—	—	—	
10	晴	29.0	25.2	3.1	7.58	—	—	—	—	—	—	
11	晴	27.3	25.9	2.6	7.63	—	—	—	—	—	—	
12	晴	27.0	25.8	2.6	7.63	—	—	—	—	—	—	
13	晴	27.1	25.7	6.6	7.59	—	—	—	—	—	—	
14	曇	28.2	25.9	3.4	7.63	—	—	—	—	—	—	
15	晴	28.4	26.0	3.5	7.62	—	—	—	—	—	—	
16	曇	31.0	25.6	3.0	7.75	—	—	—	—	—	—	
17	晴	30.0	25.8	2.8	7.63	—	—	—	—	—	—	
18	曇	27.8	26.3	2.3	7.61	—	—	—	—	—	—	
19	晴	26.3	26.5	1.8	7.73	43.7	48.4	80	4.0	0.08	<0.02	
20	曇	27.3	26.5	1.8	7.72	—	—	—	—	—	—	
21	雨	26.0	26.4	1.9	7.71	—	—	—	—	—	—	
22	曇	25.3	26.1	1.6	7.67	—	—	—	—	—	—	
23	曇	26.0	25.1	13.8	7.66	—	—	—	—	—	—	
24	晴	25.5	24.6	12.6	7.65	—	—	—	—	—	—	
25	晴	24.3	25.4	6.8	7.61	—	—	—	—	—	—	
26	晴	24.8	25.3	4.6	7.70	—	—	—	—	—	—	
27	晴	25.6	25.3	4.2	7.67	—	—	—	—	—	—	
28	晴	26.6	25.5	2.8	7.64	—	—	—	—	—	—	
29	晴	25.5	25.5	3.4	7.69	—	—	—	—	—	—	
30	晴	29.0	25.1	2.3	7.74	—	—	—	—	—	—	
平均		27.4	25.8	4.8	7.65	41.5	45.2	73	4.0	0.12	<0.02	
最高		32.0	27.0	26.5	7.75	43.7	48.4	80	4.0	0.17	<0.02	
最低		23.1	24.6	1.6	7.56	39.3	42.0	66	4.0	0.08	<0.02	

令和5年9月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	28.3	27.1	0.2	7.51	—	—	—	—	—	—	
2	晴	32.0	27.3	0.2	7.56	—	—	—	—	—	—	
3	晴	32.0	27.3	0.3	7.55	—	—	—	—	—	—	
4	曇	30.6	27.6	0.2	7.57	—	—	—	—	—	—	
5	晴	28.9	27.7	0.5	7.61	37.7	42.4	64	6.1	<0.03	<0.02	
6	雨	24.7	27.6	0.2	7.57	—	—	—	—	—	—	
7	曇	25.7	27.5	0.2	7.56	—	—	—	—	—	—	
8	曇	23.1	26.9	0.2	7.56	—	—	—	—	—	—	
9	晴	27.5	26.6	0.2	7.57	—	—	—	—	—	—	
10	晴	29.0	26.8	0.3	7.58	—	—	—	—	—	—	
11	晴	27.3	27.0	0.2	7.54	—	—	—	—	—	—	
12	晴	27.0	26.8	0.2	7.56	—	—	—	—	—	—	
13	晴	27.1	26.2	0.3	7.54	—	—	—	—	—	—	
14	曇	28.2	26.2	0.2	7.48	—	—	—	—	—	—	
15	晴	28.4	27.0	0.2	7.53	—	—	—	—	—	—	
16	曇	31.0	27.2	0.2	7.45	—	—	—	—	—	—	
17	晴	30.0	27.4	0.2	7.61	—	—	—	—	—	—	
18	曇	27.8	27.4	<0.1	7.60	—	—	—	—	—	—	
19	晴	26.3	27.4	0.2	7.63	42.3	47.2	80	6.7	<0.03	<0.02	
20	曇	27.3	27.6	0.2	7.67	—	—	—	—	—	—	
21	雨	26.0	27.4	0.2	7.70	—	—	—	—	—	—	
22	曇	25.3	27.2	0.2	7.66	—	—	—	—	—	—	
23	曇	26.0	27.0	0.3	7.60	—	—	—	—	—	—	
24	晴	25.5	26.7	0.1	7.55	—	—	—	—	—	—	
25	晴	24.3	26.5	0.2	7.56	—	—	—	—	—	—	
26	晴	24.8	26.3	0.1	7.56	—	—	—	—	—	—	
27	晴	25.6	26.4	0.2	7.61	—	—	—	—	—	—	
28	晴	26.6	26.5	0.2	7.62	—	—	—	—	—	—	
29	晴	25.5	26.6	0.1	7.63	—	—	—	—	—	—	
30	晴	29.0	26.8	0.2	7.65	—	—	—	—	—	—	
平均		27.4	27.0	0.2	7.58	40.0	44.8	72	6.4	<0.03	<0.02	
最高		32.0	27.7	0.5	7.70	42.3	47.2	80	6.7	<0.03	<0.02	
最低		23.1	26.2	<0.1	7.45	37.7	42.4	64	6.1	<0.03	<0.02	