

令和5年10月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	27.5	25.2	2.4	7.77	—	—	—	—	—	—	
2	晴	23.3	25.3	2.9	7.66	—	—	—	—	—	—	
3	晴	21.3	25.1	2.5	7.70	44.4	46.4	69	4.5	0.12	<0.02	
4	雨	19.1	24.8	2.2	7.64	—	—	—	—	—	—	
5	晴	22.5	24.5	2.3	7.65	—	—	—	—	—	—	
6	晴	18.5	23.8	2.7	7.63	—	—	—	—	—	—	
7	晴	22.0	22.3	1.5	7.64	—	—	—	—	—	—	
8	曇	18.0	22.3	1.3	7.63	—	—	—	—	—	—	
9	雨	18.5	23.0	2.6	7.68	—	—	—	—	—	—	
10	晴	20.0	23.0	3.2	7.69	—	—	—	—	—	—	
11	曇	20.7	22.6	3.4	7.66	—	—	—	—	—	—	
12	晴	19.2	22.3	5.5	7.65	—	—	—	—	—	—	
13	晴	18.3	22.1	5.6	7.68	—	—	—	—	—	—	
14	晴	20.5	20.9	1.9	7.65	—	—	—	—	—	—	
15	曇	17.0	20.8	1.9	7.69	—	—	—	—	—	—	
16	晴	18.1	21.5	4.5	7.73	42.1	42.1	78	4.6	0.24	<0.02	
17	晴	18.0	21.4	5.1	7.67	—	—	—	—	—	—	
18	晴	19.5	21.3	5.2	7.70	—	—	—	—	—	—	
19	晴	18.6	21.2	4.2	7.65	—	—	—	—	—	—	
20	晴	20.0	21.3	4.7	7.68	—	—	—	—	—	—	
21	晴	19.0	19.8	1.7	7.65	—	—	—	—	—	—	
22	晴	18.0	19.3	1.8	7.61	—	—	—	—	—	—	
23	晴	15.0	20.3	4.1	7.70	—	—	—	—	—	—	
24	晴	16.3	20.3	4.0	7.72	—	—	—	—	—	—	
25	曇	16.0	20.2	3.4	7.75	—	—	—	—	—	—	
26	晴	16.3	20.0	3.4	7.78	—	—	—	—	—	—	
27	晴	15.6	19.9	3.1	7.67	—	—	—	—	—	—	
28	晴	20.0	18.8	1.4	7.60	—	—	—	—	—	—	
29	晴	19.0	18.7	1.6	7.63	—	—	—	—	—	—	
30	晴	15.5	19.6	2.9	7.67	—	—	—	—	—	—	
31	晴	16.2	19.5	2.6	7.65	—	—	—	—	—	—	
平均		19.0	21.6	3.1	7.67	43.2	44.2	74	4.6	0.18	<0.02	
最高		27.5	25.3	5.6	7.78	44.4	46.4	78	4.6	0.24	<0.02	
最低		15.0	18.7	1.3	7.60	42.1	42.1	69	4.5	0.12	<0.02	

令和5年10月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	27.5	26.8	0.1	7.66	—	—	—	—	—	—	
2	晴	23.3	26.6	0.1	7.65	—	—	—	—	—	—	
3	晴	21.3	25.9	0.2	7.70	43.6	45.6	74	6.8	<0.03	<0.02	
4	雨	19.1	25.7	0.2	7.73	—	—	—	—	—	—	
5	晴	22.5	25.5	0.5	7.67	—	—	—	—	—	—	
6	晴	18.5	24.8	0.2	7.69	—	—	—	—	—	—	
7	晴	22.0	24.5	0.1	7.79	—	—	—	—	—	—	
8	曇	18.0	24.4	0.2	7.79	—	—	—	—	—	—	
9	雨	18.5	24.0	0.1	7.70	—	—	—	—	—	—	
10	晴	20.0	24.0	0.1	7.74	—	—	—	—	—	—	
11	曇	20.7	23.9	0.2	7.74	—	—	—	—	—	—	
12	晴	19.2	23.8	0.2	7.71	—	—	—	—	—	—	
13	晴	18.3	23.5	0.2	7.71	—	—	—	—	—	—	
14	晴	20.5	23.4	0.2	7.71	—	—	—	—	—	—	
15	曇	17.0	23.0	0.2	7.75	—	—	—	—	—	—	
16	晴	18.1	23.0	0.2	7.74	39.9	43.3	68	6.6	<0.03	<0.02	
17	晴	18.0	22.8	0.2	7.72	—	—	—	—	—	—	
18	晴	19.5	22.6	<0.1	7.73	—	—	—	—	—	—	
19	晴	18.6	22.6	0.2	7.68	—	—	—	—	—	—	
20	晴	20.0	22.6	0.1	7.71	—	—	—	—	—	—	
21	晴	19.0	21.8	0.3	7.68	—	—	—	—	—	—	
22	晴	18.0	21.3	0.4	7.68	—	—	—	—	—	—	
23	晴	15.0	21.0	0.4	7.70	—	—	—	—	—	—	
24	晴	16.3	21.1	0.2	7.75	—	—	—	—	—	—	
25	曇	16.0	21.0	0.2	7.75	—	—	—	—	—	—	
26	晴	16.3	20.8	0.2	7.74	—	—	—	—	—	—	
27	晴	15.6	20.7	0.2	7.74	—	—	—	—	—	—	
28	晴	20.0	20.6	0.2	7.69	—	—	—	—	—	—	
29	晴	19.0	20.3	0.2	7.70	—	—	—	—	—	—	
30	晴	15.5	20.4	0.2	7.64	—	—	—	—	—	—	
31	晴	16.2	20.3	0.1	7.63	—	—	—	—	—	—	
平均		19.0	23.0	0.2	7.71	41.8	44.4	71	6.7	<0.03	<0.02	
最高		27.5	26.8	0.5	7.79	43.6	45.6	74	6.8	<0.03	<0.02	
最低		15.0	20.3	<0.1	7.63	39.9	43.3	68	6.6	<0.03	<0.02	