

令和5年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	16.2	19.5	2.4	7.70	—	—	—	—	—	—	
2	晴	17.0	19.3	2.2	7.69	—	—	—	—	—	—	
3	晴	18.5	19.3	2.3	7.69	—	—	—	—	—	—	
4	晴	22.0	18.5	1.4	7.62	—	—	—	—	—	—	
5	曇	21.0	18.6	1.4	7.65	—	—	—	—	—	—	
6	曇	22.1	19.5	2.3	7.68	—	—	—	—	—	—	
7	雨	20.5	20.0	2.3	7.61	43.3	44.0	68	6.2	0.22	<0.02	
8	晴	16.0	19.4	2.8	7.65	—	—	—	—	—	—	
9	曇	16.4	19.2	26.5	7.60	—	—	—	—	—	—	
10	雨	17.2	19.1	7.0	7.61	—	—	—	—	—	—	
11	曇	14.0	17.8	3.9	7.31	—	—	—	—	—	—	
12	晴	15.0	17.5	2.7	7.28	—	—	—	—	—	—	
13	曇	11.8	18.1	4.3	7.60	—	—	—	—	—	—	
14	晴	9.6	17.6	3.4	7.64	—	—	—	—	—	—	
15	曇	11.4	17.3	5.8	7.68	—	—	—	—	—	—	
16	晴	9.8	17.1	4.3	7.67	—	—	—	—	—	—	
17	雨	13.6	16.5	5.0	7.66	—	—	—	—	—	—	
18	晴	11.5	15.5	4.9	7.61	—	—	—	—	—	—	
19	晴	14.0	14.8	6.2	7.62	—	—	—	—	—	—	
20	晴	12.3	15.6	5.6	7.62	39.3	40.3	84	4.1	0.33	<0.02	
21	曇	10.5	15.2	5.1	7.62	—	—	—	—	—	—	
22	晴	12.9	15.7	4.1	7.65	—	—	—	—	—	—	
23	晴	13.8	15.7	3.9	7.65	—	—	—	—	—	—	
24	晴	13.2	15.6	5.0	7.67	—	—	—	—	—	—	
25	晴	11.0	14.0	2.9	7.63	—	—	—	—	—	—	
26	曇	15.5	14.0	4.2	7.61	—	—	—	—	—	—	
27	晴	10.5	15.0	3.7	7.65	—	—	—	—	—	—	
28	晴	13.5	15.1	4.0	7.68	—	—	—	—	—	—	
29	晴	8.3	14.7	3.7	7.67	—	—	—	—	—	—	
30	曇	11.0	14.6	3.5	7.66	—	—	—	—	—	—	
平均		14.3	17.0	4.6	7.62	41.3	42.2	76	5.2	0.28	<0.02	
最高		22.1	20.0	26.5	7.70	43.3	44.0	84	6.2	0.33	<0.02	
最低		8.3	14.0	1.4	7.28	39.3	40.3	68	4.1	0.22	<0.02	

令和5年11月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	16.2	20.3	0.1	7.65	—	—	—	—	—	—	
2	晴	17.0	20.1	0.3	7.63	—	—	—	—	—	—	
3	晴	18.5	20.2	0.2	7.63	—	—	—	—	—	—	
4	晴	22.0	20.3	0.3	7.63	—	—	—	—	—	—	
5	曇	21.0	20.3	0.2	7.60	—	—	—	—	—	—	
6	曇	22.1	20.4	0.1	7.62	—	—	—	—	—	—	
7	雨	20.5	20.5	0.3	7.56	41.1	43.5	69	8.4	<0.03	<0.02	
8	晴	16.0	20.1	0.2	7.58	—	—	—	—	—	—	
9	曇	16.4	20.1	0.3	7.45	—	—	—	—	—	—	
10	雨	17.2	19.9	0.3	7.39	—	—	—	—	—	—	
11	曇	14.0	19.6	0.6	7.42	—	—	—	—	—	—	
12	晴	15.0	19.4	0.4	7.47	—	—	—	—	—	—	
13	曇	11.8	19.0	0.2	7.48	—	—	—	—	—	—	
14	晴	9.6	18.5	0.2	7.51	—	—	—	—	—	—	
15	曇	11.4	18.1	0.2	7.50	—	—	—	—	—	—	
16	晴	9.8	17.8	0.2	7.51	—	—	—	—	—	—	
17	雨	13.6	17.1	0.2	7.51	—	—	—	—	—	—	
18	晴	11.5	16.9	0.3	7.55	—	—	—	—	—	—	
19	晴	14.0	16.4	0.3	7.55	—	—	—	—	—	—	
20	晴	12.3	16.4	0.1	7.48	38.2	40.2	89	7.1	<0.03	<0.02	
21	曇	10.5	16.0	0.1	7.54	—	—	—	—	—	—	
22	晴	12.9	16.5	0.2	7.49	—	—	—	—	—	—	
23	晴	13.8	16.6	0.2	7.47	—	—	—	—	—	—	
24	晴	13.2	16.5	0.1	7.52	—	—	—	—	—	—	
25	晴	11.0	16.3	0.1	7.51	—	—	—	—	—	—	
26	曇	15.5	16.1	0.3	7.56	—	—	—	—	—	—	
27	晴	10.5	15.9	0.2	7.55	—	—	—	—	—	—	
28	晴	13.5	16.0	0.2	7.54	—	—	—	—	—	—	
29	晴	8.3	15.6	0.2	7.51	—	—	—	—	—	—	
30	曇	11.0	15.3	0.2	7.52	—	—	—	—	—	—	
平均		14.3	18.1	0.2	7.53	39.6	41.8	79	7.8	<0.03	<0.02	
最高		22.1	20.5	0.6	7.65	41.1	43.5	89	8.4	<0.03	<0.02	
最低		8.3	15.3	0.1	7.39	38.2	40.2	69	7.1	<0.03	<0.02	