

令和6年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	10.5	9.2	6.0	7.63	—	—	—	—	—	—	
2	雨	7.7	10.6	5.0	7.64	—	—	—	—	—	—	
3	曇	6.1	10.5	4.3	7.61	—	—	—	—	—	—	
4	晴	8.0	10.5	4.4	7.57	—	—	—	—	—	—	
5	晴	7.0	10.3	4.2	7.61	—	—	—	—	—	—	
6	晴	11.0	8.8	4.7	7.56	—	—	—	—	—	—	
7	晴	8.0	8.7	4.1	7.54	—	—	—	—	—	—	
8	晴	2.9	9.9	3.3	7.61	—	—	—	—	—	—	
9	晴	5.3	9.8	2.8	7.59	—	—	—	—	—	—	
10	晴	5.0	9.7	2.8	7.50	43.6	46.9	62	5.0	0.19	0.04	
11	曇	7.0	9.8	2.5	7.55	—	—	—	—	—	—	
12	晴	3.8	9.5	3.3	7.52	—	—	—	—	—	—	
13	晴	9.0	8.2	4.3	7.55	—	—	—	—	—	—	
14	晴	6.0	7.9	4.2	7.54	—	—	—	—	—	—	
15	曇	9.6	9.6	3.8	7.60	—	—	—	—	—	—	
16	晴	2.1	9.2	3.5	7.62	—	—	—	—	—	—	
17	晴	4.1	9.0	3.7	7.63	—	—	—	—	—	—	
18	曇	10.8	9.1	3.7	7.56	—	—	—	—	—	—	
19	曇	12.3	9.4	4.1	7.61	—	—	—	—	—	—	
20	雨	8.0	8.1	4.8	7.63	—	—	—	—	—	—	
21	雨	11.5	8.7	4.7	7.60	—	—	—	—	—	—	
22	曇	10.3	9.8	4.2	7.59	46.8	50.5	98	5.3	0.30	0.09	
23	晴	6.0	9.7	4.2	7.53	—	—	—	—	—	—	
24	晴	0.5	9.1	5.4	7.63	—	—	—	—	—	—	
25	晴	0.7	8.8	5.6	7.63	—	—	—	—	—	—	
26	晴	4.1	8.6	7.2	7.62	—	—	—	—	—	—	
27	晴	8.0	6.8	9.8	7.65	—	—	—	—	—	—	
28	晴	4.5	6.8	10.2	7.55	—	—	—	—	—	—	
29	晴	4.0	8.5	7.4	7.68	—	—	—	—	—	—	
30	晴	4.1	8.7	7.3	7.60	—	—	—	—	—	—	
31	曇	7.8	8.9	6.8	7.59	—	—	—	—	—	—	
平均		6.6	9.1	4.9	7.59	45.2	48.7	80	5.2	0.24	0.06	
最高		12.3	10.6	10.2	7.68	46.8	50.5	98	5.3	0.30	0.09	
最低		0.5	6.8	2.5	7.50	43.6	46.9	62	5.0	0.19	0.04	

令和6年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	10.5	12.8	0.2	7.40	—	—	—	—	—	—	
2	雨	7.7	12.8	0.2	7.45	—	—	—	—	—	—	
3	曇	6.1	12.5	0.1	7.43	—	—	—	—	—	—	
4	晴	8.0	12.6	0.2	7.41	—	—	—	—	—	—	
5	晴	7.0	12.5	0.2	7.45	—	—	—	—	—	—	
6	晴	11.0	12.5	0.3	7.46	—	—	—	—	—	—	
7	晴	8.0	12.5	0.3	7.45	—	—	—	—	—	—	
8	晴	2.9	12.1	0.1	7.48	—	—	—	—	—	—	
9	晴	5.3	11.7	0.2	7.44	—	—	—	—	—	—	
10	晴	5.0	11.6	0.2	7.43	40.5	47.1	65	7.7	0.04	<0.02	
11	曇	7.0	11.8	0.1	7.41	—	—	—	—	—	—	
12	晴	3.8	11.5	0.2	7.38	—	—	—	—	—	—	
13	晴	9.0	11.5	0.3	7.36	—	—	—	—	—	—	
14	晴	6.0	11.2	0.4	7.42	—	—	—	—	—	—	
15	曇	9.6	11.3	0.3	7.49	—	—	—	—	—	—	
16	晴	2.1	11.1	0.3	7.47	—	—	—	—	—	—	
17	晴	4.1	10.8	0.2	7.50	—	—	—	—	—	—	
18	曇	10.8	11.0	0.3	7.41	—	—	—	—	—	—	
19	曇	12.3	11.2	0.3	7.48	—	—	—	—	—	—	
20	雨	8.0	11.3	0.2	7.44	—	—	—	—	—	—	
21	雨	11.5	11.5	0.2	7.49	—	—	—	—	—	—	
22	曇	10.3	11.7	0.1	7.51	44.1	50.3	96	8.0	<0.03	0.03	
23	晴	6.0	11.5	0.4	7.51	—	—	—	—	—	—	
24	晴	0.5	11.1	0.2	7.52	—	—	—	—	—	—	
25	晴	0.7	10.5	0.3	7.52	—	—	—	—	—	—	
26	晴	4.1	10.4	0.2	7.55	—	—	—	—	—	—	
27	晴	8.0	10.1	0.3	7.47	—	—	—	—	—	—	
28	晴	4.5	10.1	0.3	7.49	—	—	—	—	—	—	
29	晴	4.0	10.3	0.2	7.53	—	—	—	—	—	—	
30	晴	4.1	10.3	0.2	7.52	—	—	—	—	—	—	
31	曇	7.8	10.5	0.3	7.48	—	—	—	—	—	—	
平均		6.6	11.4	0.2	7.46	42.3	48.7	80	7.8	<0.03	<0.02	
最高		12.3	12.8	0.4	7.55	44.1	50.3	96	8.0	0.04	0.03	
最低		0.5	10.1	0.1	7.36	40.5	47.1	65	7.7	<0.03	<0.02	