

令和6年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	10.4	9.1	5.8	7.59	—	—	—	—	—	—	
2	曇	8.1	9.1	5.5	7.61	—	—	—	—	—	—	
3	晴	8.0	7.5	7.0	7.42	—	—	—	—	—	—	
4	雨	6.5	7.7	6.4	7.68	—	—	—	—	—	—	
5	曇	7.8	9.1	4.2	7.57	—	—	—	—	—	—	
6	曇	5.6	9.1	3.5	7.59	42.6	44.7	67	5.8	0.26	0.05	
7	晴	4.7	8.9	3.6	7.62	—	—	—	—	—	—	
8	晴	3.5	9.0	3.0	7.58	—	—	—	—	—	—	
9	曇	6.8	9.1	2.4	7.60	—	—	—	—	—	—	
10	晴	6.5	7.5	3.2	7.69	—	—	—	—	—	—	
11	晴	9.5	7.6	3.8	7.59	—	—	—	—	—	—	
12	晴	5.3	9.0	3.5	7.63	—	—	—	—	—	—	
13	晴	4.9	9.0	3.6	7.59	—	—	—	—	—	—	
14	晴	9.3	9.2	3.7	7.63	—	—	—	—	—	—	
15	曇	12.3	9.5	3.8	7.58	—	—	—	—	—	—	
16	晴	9.7	9.8	3.7	7.61	—	—	—	—	—	—	
17	曇	13.5	8.7	5.4	7.70	—	—	—	—	—	—	
18	曇	13.0	9.0	5.0	7.71	—	—	—	—	—	—	
19	雨	15.6	10.2	5.8	7.57	43.1	49.3	102	7.4	0.40	0.06	
20	晴	16.6	11.0	6.3	7.56	—	—	—	—	—	—	
21	雨	14.8	12.1	105.2	7.45	—	—	—	—	—	—	
22	雨	12.3	12.0	28.2	7.47	—	—	—	—	—	—	
23	雨	8.3	11.4	22.0	7.50	—	—	—	—	—	—	
24	曇	6.0	10.4	33.0	7.34	—	—	—	—	—	—	
25	雨	5.0	10.1	30.2	7.27	—	—	—	—	—	—	
26	晴	8.4	10.8	20.3	7.57	—	—	—	—	—	—	
27	晴	4.8	10.4	23.5	7.53	—	—	—	—	—	—	
28	晴	5.9	10.3	33.8	7.55	—	—	—	—	—	—	
29	曇	7.8	10.4	37.9	7.49	—	—	—	—	—	—	
平均		8.7	9.6	14.6	7.56	42.8	47.0	84	6.6	0.33	0.06	
最高		16.6	12.1	105.2	7.71	43.1	49.3	102	7.4	0.40	0.06	
最低		3.5	7.5	2.4	7.27	42.6	44.7	67	5.8	0.26	0.05	

令和6年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	10.4	10.7	0.2	7.49	—	—	—	—	—	—	
2	曇	8.1	10.8	0.3	7.47	—	—	—	—	—	—	
3	晴	8.0	10.7	0.5	7.46	—	—	—	—	—	—	
4	雨	6.5	10.8	0.2	7.49	—	—	—	—	—	—	
5	曇	7.8	10.8	0.2	7.48	—	—	—	—	—	—	
6	曇	5.6	10.7	0.1	7.47	41.0	47.1	72	9.8	0.03	0.03	
7	晴	4.7	10.6	0.1	7.48	—	—	—	—	—	—	
8	晴	3.5	10.5	0.2	7.49	—	—	—	—	—	—	
9	曇	6.8	10.6	0.1	7.51	—	—	—	—	—	—	
10	晴	6.5	10.6	0.1	7.48	—	—	—	—	—	—	
11	晴	9.5	10.7	<0.1	7.55	—	—	—	—	—	—	
12	晴	5.3	10.7	0.3	7.58	—	—	—	—	—	—	
13	晴	4.9	10.6	0.3	7.52	—	—	—	—	—	—	
14	晴	9.3	10.8	0.1	7.54	—	—	—	—	—	—	
15	曇	12.3	11.3	0.2	7.52	—	—	—	—	—	—	
16	晴	9.7	11.5	0.2	7.52	—	—	—	—	—	—	
17	曇	13.5	11.6	0.2	7.47	—	—	—	—	—	—	
18	曇	13.0	11.8	0.2	7.51	—	—	—	—	—	—	
19	雨	15.6	15.6	0.1	7.51	39.9	49.1	98	9.4	0.04	0.02	
20	晴	16.6	12.5	0.3	7.52	—	—	—	—	—	—	
21	雨	14.8	13.1	0.4	7.39	—	—	—	—	—	—	
22	雨	12.3	13.4	0.4	7.26	—	—	—	—	—	—	
23	雨	8.3	13.1	0.5	7.25	—	—	—	—	—	—	
24	曇	6.0	12.6	0.2	7.27	—	—	—	—	—	—	
25	雨	5.0	12.6	0.3	7.25	—	—	—	—	—	—	
26	晴	8.4	12.5	0.2	7.36	—	—	—	—	—	—	
27	晴	4.8	12.1	0.4	7.32	—	—	—	—	—	—	
28	晴	5.9	12.0	0.2	7.37	—	—	—	—	—	—	
29	曇	7.8	12.0	0.3	7.30	—	—	—	—	—	—	
平均		8.7	11.6	0.2	7.44	40.4	48.1	85	9.6	0.04	0.02	
最高		16.6	15.6	0.5	7.58	41.0	49.1	98	9.8	0.04	0.03	
最低		3.5	10.5	<0.1	7.25	39.9	47.1	72	9.4	0.03	0.02	