

令和6年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	9.6	10.6	40.2	7.58	—	—	—	—	—	—	
2	曇	5.5	9.1	57.6	7.60	—	—	—	—	—	—	
3	晴	9.0	8.8	42.1	7.57	—	—	—	—	—	—	
4	曇	5.5	9.8	27.1	7.65	—	—	—	—	—	—	
5	雨	9.4	10.0	25.2	7.55	32.8	37.1	75	5.4	1.10	0.06	
6	雨	8.8	9.9	22.4	7.62	—	—	—	—	—	—	
7	曇	7.6	9.8	16.0	7.60	—	—	—	—	—	—	
8	晴	6.8	9.7	16.6	7.63	—	—	—	—	—	—	
9	晴	6.0	8.5	15.8	7.66	—	—	—	—	—	—	
10	晴	8.0	8.4	15.9	7.68	—	—	—	—	—	—	
11	晴	5.7	9.7	14.1	7.65	34.4	40.8	69	4.3	0.74	0.04	
12	雨	9.9	10.0	13.5	7.50	—	—	—	—	—	—	
13	晴	7.0	9.9	14.4	7.68	—	—	—	—	—	—	
14	晴	5.8	9.8	20.4	7.61	—	—	—	—	—	—	
15	晴	9.9	10.0	12.1	7.60	—	—	—	—	—	—	
16	晴	16.5	9.0	9.4	7.68	—	—	—	—	—	—	
17	晴	17.9	9.3	8.0	7.54	—	—	—	—	—	—	
18	晴	9.7	10.7	7.9	7.64	—	—	—	—	—	—	
19	曇	7.0	10.5	6.0	7.63	—	—	—	—	—	—	
20	晴	11.4	10.6	5.6	7.63	—	—	—	—	—	—	
21	晴	3.8	10.0	5.0	7.66	—	—	—	—	—	—	
22	晴	5.0	10.0	4.6	7.64	—	—	—	—	—	—	
23	雨	7.0	9.0	4.0	7.64	—	—	—	—	—	—	
24	曇	9.0	8.8	3.8	7.61	—	—	—	—	—	—	
25	雨	11.2	10.1	4.5	7.63	—	—	—	—	—	—	
26	雨	8.8	10.3	3.8	7.63	—	—	—	—	—	—	
27	晴	10.8	10.4	6.4	7.61	—	—	—	—	—	—	
28	曇	12.3	10.8	6.7	7.56	—	—	—	—	—	—	
29	雨	16.8	11.5	5.8	7.61	—	—	—	—	—	—	
30	晴	19.0	11.2	112.8	7.62	—	—	—	—	—	—	
31	晴	20.0	11.0	30.7	7.44	—	—	—	—	—	—	
平均		9.7	9.9	18.7	7.61	33.6	39.0	72	4.8	0.92	0.05	
最高		20.0	11.5	112.8	7.68	34.4	40.8	75	5.4	1.10	0.06	
最低		3.8	8.4	3.8	7.44	32.8	37.1	69	4.3	0.74	0.04	

令和6年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	9.6	12.1	0.3	7.35	—	—	—	—	—	—	
2	曇	5.5	12.0	0.4	7.36	—	—	—	—	—	—	
3	晴	9.0	11.5	0.4	7.40	—	—	—	—	—	—	
4	曇	5.5	11.6	0.5	7.39	—	—	—	—	—	—	
5	雨	9.4	11.6	0.3	7.39	29.4	37.8	61	8.7	0.04	<0.02	
6	雨	8.8	11.4	0.5	7.39	—	—	—	—	—	—	
7	曇	7.6	11.3	0.4	7.30	—	—	—	—	—	—	
8	晴	6.8	11.3	0.4	7.36	—	—	—	—	—	—	
9	晴	6.0	11.3	0.4	7.42	—	—	—	—	—	—	
10	晴	8.0	11.1	0.4	7.47	—	—	—	—	—	—	
11	晴	5.7	11.3	0.6	7.50	32.0	39.3	53	8.5	0.05	<0.02	
12	雨	9.9	11.6	0.5	7.45	—	—	—	—	—	—	
13	晴	7.0	11.5	0.5	7.46	—	—	—	—	—	—	
14	晴	5.8	11.4	0.7	7.43	—	—	—	—	—	—	
15	晴	9.9	11.6	0.4	7.41	—	—	—	—	—	—	
16	晴	16.5	12.0	0.5	7.45	—	—	—	—	—	—	
17	晴	17.9	12.2	0.4	7.44	—	—	—	—	—	—	
18	晴	9.7	12.3	0.4	7.46	—	—	—	—	—	—	
19	曇	7.0	12.1	0.5	7.44	—	—	—	—	—	—	
20	晴	11.4	12.1	0.3	7.47	—	—	—	—	—	—	
21	晴	3.8	11.8	0.5	7.52	—	—	—	—	—	—	
22	晴	5.0	11.5	0.4	7.49	—	—	—	—	—	—	
23	雨	7.0	11.6	0.4	7.50	—	—	—	—	—	—	
24	曇	9.0	11.6	0.5	7.48	—	—	—	—	—	—	
25	雨	11.2	11.7	0.2	7.46	—	—	—	—	—	—	
26	雨	8.8	11.7	0.3	7.44	—	—	—	—	—	—	
27	晴	10.8	11.8	0.3	7.45	—	—	—	—	—	—	
28	曇	12.3	12.2	0.4	7.40	—	—	—	—	—	—	
29	雨	16.8	12.7	0.6	7.42	—	—	—	—	—	—	
30	晴	19.0	13.0	0.4	7.38	—	—	—	—	—	—	
31	晴	20.0	13.4	0.3	7.36	—	—	—	—	—	—	
平均		9.7	11.8	0.4	7.43	30.7	38.6	57	8.6	0.04	<0.02	
最高		20.0	13.4	0.7	7.52	32.0	39.3	61	8.7	0.05	<0.02	
最低		3.8	11.1	0.2	7.30	29.4	37.8	53	8.5	0.04	<0.02	