

令和6年6月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	22.5	19.2	117.8	7.65	—	—	—	—	—	—	
2	曇	23.3	19.3	103.1	7.67	—	—	—	—	—	—	
3	曇	20.6	19.0	91.4	7.67	—	—	—	—	—	—	
4	晴	21.4	19.1	91.4	7.65	32.4	35.2	106	2.6	3.70	0.10	
5	晴	21.5	19.3	55.5	7.70	—	—	—	—	—	—	
6	晴	23.3	19.5	56.4	7.73	—	—	—	—	—	—	
7	晴	23.4	19.5	49.1	7.73	—	—	—	—	—	—	
8	晴	24.3	19.5	44.7	7.73	—	—	—	—	—	—	
9	曇	22.5	19.6	38.7	7.68	—	—	—	—	—	—	
10	晴	23.3	19.6	34.3	7.71	—	—	—	—	—	—	
11	晴	23.5	19.8	27.6	7.65	—	—	—	—	—	—	
12	晴	24.7	20.1	23.2	7.69	—	—	—	—	—	—	
13	曇	24.3	20.2	22.2	7.70	—	—	—	—	—	—	
14	晴	25.0	20.4	18.2	7.70	—	—	—	—	—	—	
15	晴	26.3	20.7	15.7	7.70	—	—	—	—	—	—	
16	曇	23.8	20.8	13.3	7.67	—	—	—	—	—	—	
17	晴	25.4	21.1	12.0	7.63	—	—	—	—	—	—	
18	雨	18.9	21.0	11.7	7.67	37.8	38.4	68	3.0	0.47	0.02	
19	晴	21.6	20.6	49.5	7.66	—	—	—	—	—	—	
20	晴	24.6	21.1	15.3	7.65	—	—	—	—	—	—	
21	雨	19.1	21.0	12.5	7.67	—	—	—	—	—	—	
22	晴	26.1	20.6	24.8	7.67	—	—	—	—	—	—	
23	雨	22.7	20.9	23.1	7.65	—	—	—	—	—	—	
24	晴	27.3	21.1	42.8	7.69	—	—	—	—	—	—	
25	曇	28.6	21.2	34.0	7.66	—	—	—	—	—	—	
26	晴	27.8	21.1	80.5	7.68	—	—	—	—	—	—	
27	晴	25.0	21.2	98.0	7.71	—	—	—	—	—	—	
28	雨	22.1	21.5	82.8	7.73	—	—	—	—	—	—	
29	曇	26.0	21.5	159.6	7.61	—	—	—	—	—	—	
30	曇	26.0	21.3	167.3	7.71	—	—	—	—	—	—	
平均		23.8	20.4	53.9	7.68	35.1	36.8	87	2.8	2.08	0.06	
最高		28.6	21.5	167.3	7.73	37.8	38.4	106	3.0	3.70	0.10	
最低		18.9	19.0	11.7	7.61	32.4	35.2	68	2.6	0.47	0.02	

令和6年6月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	22.5	20.3	0.6	7.29	—	—	—	—	—	—	
2	曇	23.3	20.3	0.3	7.28	—	—	—	—	—	—	
3	曇	20.6	20.3	0.5	7.32	—	—	—	—	—	—	
4	晴	21.4	20.3	0.3	7.31	28.8	34.1	42	7.5	0.04	<0.02	
5	晴	21.5	20.4	0.3	7.33	—	—	—	—	—	—	
6	晴	23.3	20.6	0.3	7.36	—	—	—	—	—	—	
7	晴	23.4	20.7	0.3	7.36	—	—	—	—	—	—	
8	晴	24.3	20.8	0.4	7.47	—	—	—	—	—	—	
9	曇	22.5	20.9	0.3	7.40	—	—	—	—	—	—	
10	晴	23.3	20.9	0.4	7.42	—	—	—	—	—	—	
11	晴	23.5	21.0	0.3	7.41	—	—	—	—	—	—	
12	晴	24.7	21.3	0.2	7.38	—	—	—	—	—	—	
13	曇	24.3	21.5	0.4	7.41	—	—	—	—	—	—	
14	晴	25.0	21.6	0.2	7.42	—	—	—	—	—	—	
15	晴	26.3	21.9	0.2	7.47	—	—	—	—	—	—	
16	曇	23.8	22.0	0.2	7.45	—	—	—	—	—	—	
17	晴	25.4	22.1	0.3	7.46	—	—	—	—	—	—	
18	雨	18.9	22.0	0.3	7.47	34.0	38.6	70	6.5	0.03	<0.02	
19	晴	21.6	21.9	0.3	7.41	—	—	—	—	—	—	
20	晴	24.6	22.1	0.3	7.40	—	—	—	—	—	—	
21	雨	19.1	22.0	0.4	7.40	—	—	—	—	—	—	
22	晴	26.1	22.1	0.3	7.47	—	—	—	—	—	—	
23	雨	22.7	22.1	0.2	7.40	—	—	—	—	—	—	
24	晴	27.3	22.3	0.2	7.44	—	—	—	—	—	—	
25	曇	28.6	22.6	0.2	7.42	—	—	—	—	—	—	
26	晴	27.8	22.6	0.3	7.40	—	—	—	—	—	—	
27	晴	25.0	22.5	0.4	7.36	—	—	—	—	—	—	
28	雨	22.1	22.6	0.4	7.34	—	—	—	—	—	—	
29	曇	26.0	22.8	0.3	7.40	—	—	—	—	—	—	
30	曇	26.0	23.0	0.2	7.32	—	—	—	—	—	—	
平均		23.8	21.6	0.3	7.39	31.4	36.4	56	7.0	0.04	<0.02	
最高		28.6	23.0	0.6	7.47	34.0	38.6	70	7.5	0.04	<0.02	
最低		18.9	20.3	0.2	7.28	28.8	34.1	42	6.5	0.03	<0.02	