

令和6年9月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	28.7	24.9	103.1	7.59	—	—	—	—	—	—	
2	曇	29.2	24.6	45.2	7.59	—	—	—	—	—	—	
3	晴	27.8	24.5	32.5	7.62	30.6	32.9	62	2.3	1.40	0.05	
4	晴	25.5	24.8	22.3	7.58	—	—	—	—	—	—	
5	晴	26.6	24.8	16.9	7.57	—	—	—	—	—	—	
6	晴	27.2	25.0	13.7	7.54	—	—	—	—	—	—	
7	晴	28.8	25.1	10.4	7.59	—	—	—	—	—	—	
8	晴	30.0	25.4	8.4	7.56	—	—	—	—	—	—	
9	晴	28.5	25.5	7.7	7.57	—	—	—	—	—	—	
10	晴	28.6	25.7	5.4	7.59	—	—	—	—	—	—	
11	晴	27.4	25.9	4.0	7.59	—	—	—	—	—	—	
12	晴	28.7	26.0	4.4	7.57	—	—	—	—	—	—	
13	晴	28.7	26.1	4.2	7.60	—	—	—	—	—	—	
14	晴	28.5	26.1	7.3	7.60	—	—	—	—	—	—	
15	晴	29.0	26.3	4.0	7.62	—	—	—	—	—	—	
16	晴	28.6	26.3	6.4	7.56	—	—	—	—	—	—	
17	晴	27.8	26.3	4.9	7.60	34.6	35.4	73	2.8	0.21	<0.02	
18	晴	29.2	26.4	2.9	7.65	—	—	—	—	—	—	
19	晴	29.9	26.6	2.3	7.65	—	—	—	—	—	—	
20	晴	28.2	26.7	3.2	7.62	—	—	—	—	—	—	
21	曇	30.3	26.7	2.2	7.70	—	—	—	—	—	—	
22	曇	28.8	26.8	2.2	7.68	—	—	—	—	—	—	
23	曇	26.0	26.4	2.2	7.67	—	—	—	—	—	—	
24	晴	23.4	26.1	3.2	7.65	—	—	—	—	—	—	
25	曇	24.4	25.9	3.8	7.65	—	—	—	—	—	—	
26	曇	26.6	25.8	3.1	7.60	—	—	—	—	—	—	
27	曇	25.3	25.8	2.4	7.65	—	—	—	—	—	—	
28	曇	26.1	25.6	2.1	7.62	—	—	—	—	—	—	
29	曇	25.5	25.5	2.0	7.64	—	—	—	—	—	—	
30	晴	24.3	25.3	1.2	7.64	—	—	—	—	—	—	
平均		27.6	25.8	11.1	7.61	32.6	34.2	68	2.6	0.80	0.02	
最高		30.3	26.8	103.1	7.70	34.6	35.4	73	2.8	1.40	0.05	
最低		23.4	24.5	1.2	7.54	30.6	32.9	62	2.3	0.21	<0.02	

令和6年9月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	曇	28.7	26.3	0.1	7.34	—	—	—	—	—	—	
2	曇	29.2	26.3	0.2	7.31	—	—	—	—	—	—	
3	晴	27.8	26.0	0.2	7.34	25.5	29.7	28	7.3	0.04	<0.02	
4	晴	25.5	25.8	0.3	7.38	—	—	—	—	—	—	
5	晴	26.6	25.8	0.2	7.36	—	—	—	—	—	—	
6	晴	27.2	25.9	0.2	7.35	—	—	—	—	—	—	
7	晴	28.8	26.1	0.1	7.41	—	—	—	—	—	—	
8	晴	30.0	26.3	0.2	7.44	—	—	—	—	—	—	
9	晴	28.5	26.5	0.1	7.47	—	—	—	—	—	—	
10	晴	28.6	26.6	0.2	7.47	—	—	—	—	—	—	
11	晴	27.4	26.7	0.2	7.45	—	—	—	—	—	—	
12	晴	28.7	26.9	0.1	7.45	—	—	—	—	—	—	
13	晴	28.7	27.0	0.2	7.52	—	—	—	—	—	—	
14	晴	28.5	27.0	0.1	7.53	—	—	—	—	—	—	
15	晴	29.0	27.1	0.1	7.52	—	—	—	—	—	—	
16	晴	28.6	27.2	0.2	7.50	—	—	—	—	—	—	
17	晴	27.8	27.1	<0.1	7.52	33.2	34.5	71	6.3	<0.03	<0.02	
18	晴	29.2	27.2	0.1	7.50	—	—	—	—	—	—	
19	晴	29.9	27.3	0.1	7.57	—	—	—	—	—	—	
20	晴	28.2	27.5	0.2	7.57	—	—	—	—	—	—	
21	曇	30.3	27.6	<0.1	7.68	—	—	—	—	—	—	
22	曇	28.8	27.6	0.1	7.62	—	—	—	—	—	—	
23	曇	26.0	27.3	<0.1	7.65	—	—	—	—	—	—	
24	晴	23.4	27.0	0.2	7.57	—	—	—	—	—	—	
25	曇	24.4	26.6	0.1	7.62	—	—	—	—	—	—	
26	曇	26.6	26.6	0.1	7.55	—	—	—	—	—	—	
27	曇	25.3	26.6	0.1	7.61	—	—	—	—	—	—	
28	曇	26.1	26.6	<0.1	7.63	—	—	—	—	—	—	
29	曇	25.5	26.5	<0.1	7.58	—	—	—	—	—	—	
30	晴	24.3	26.3	0.1	7.62	—	—	—	—	—	—	
平均		27.6	26.7	0.1	7.50	29.4	32.1	50	6.8	<0.03	<0.02	
最高		30.3	27.6	0.3	7.68	33.2	34.5	71	7.3	0.04	<0.02	
最低		23.4	25.8	<0.1	7.31	25.5	29.7	28	6.3	<0.03	<0.02	