

令和6年12月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	10.6	15.1	6.1	7.78	—	—	—	—	—	—	
2	晴	9.0	15.0	5.5	7.73	—	—	—	—	—	—	
3	晴	10.6	15.0	5.2	7.74	38.4	41.0	53	3.7	0.33	<0.02	
4	晴	12.8	14.9	4.8	7.73	—	—	—	—	—	—	
5	晴	9.6	14.6	4.3	7.74	—	—	—	—	—	—	
6	晴	9.1	14.5	3.8	7.77	—	—	—	—	—	—	
7	晴	9.1	14.1	3.8	7.77	—	—	—	—	—	—	
8	曇	7.6	14.1	4.1	7.74	—	—	—	—	—	—	
9	晴	5.0	13.6	4.0	7.76	—	—	—	—	—	—	
10	晴	5.8	13.4	3.2	7.74	—	—	—	—	—	—	
11	晴	7.3	13.4	3.2	7.72	—	—	—	—	—	—	
12	晴	5.1	13.1	3.3	7.73	—	—	—	—	—	—	
13	曇	5.8	12.9	3.1	7.72	—	—	—	—	—	—	
14	晴	8.0	12.8	4.3	7.74	—	—	—	—	—	—	
15	晴	5.9	12.6	3.2	7.76	—	—	—	—	—	—	
16	晴	5.3	12.5	2.8	7.78	—	—	—	—	—	—	
17	晴	6.1	12.4	5.2	7.75	38.8	39.7	64	4.0	0.30	<0.02	
18	晴	5.5	12.2	3.6	7.71	—	—	—	—	—	—	
19	晴	4.8	12.0	3.4	7.72	—	—	—	—	—	—	
20	晴	4.5	11.6	3.4	7.74	—	—	—	—	—	—	
21	曇	9.4	11.5	3.0	7.76	—	—	—	—	—	—	
22	晴	6.6	11.5	3.1	7.75	—	—	—	—	—	—	
23	晴	2.7	11.1	2.7	7.80	—	—	—	—	—	—	
24	晴	4.8	11.1	2.7	7.79	—	—	—	—	—	—	
25	晴	3.8	11.0	2.4	7.73	—	—	—	—	—	—	
26	曇	9.6	11.1	3.1	7.75	—	—	—	—	—	—	
27	晴	6.9	11.1	2.4	7.75	—	—	—	—	—	—	
28	晴	6.8	10.8	2.6	7.80	—	—	—	—	—	—	
29	晴	5.0	10.8	2.6	7.77	—	—	—	—	—	—	
30	晴	2.8	10.6	2.4	7.73	—	—	—	—	—	—	
31	曇	7.9	10.6	2.6	7.70	—	—	—	—	—	—	
平均		6.9	12.6	3.5	7.75	38.6	40.4	58	3.8	0.32	<0.02	
最高		12.8	15.1	6.1	7.80	38.8	41.0	64	4.0	0.33	<0.02	
最低		2.7	10.6	2.4	7.70	38.4	39.7	53	3.7	0.30	<0.02	

令和6年12月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	10.6	16.8	0.2	7.60	—	—	—	—	—	—	
2	晴	9.0	16.7	0.2	7.62	—	—	—	—	—	—	
3	晴	10.6	16.6	0.1	7.53	35.5	39.7	58	8.0	<0.03	<0.02	
4	晴	12.8	16.7	0.4	7.55	—	—	—	—	—	—	
5	晴	9.6	16.4	0.3	7.58	—	—	—	—	—	—	
6	晴	9.1	16.1	0.5	7.57	—	—	—	—	—	—	
7	晴	9.1	15.9	0.4	7.63	—	—	—	—	—	—	
8	曇	7.6	15.8	0.2	7.60	—	—	—	—	—	—	
9	晴	5.0	15.3	0.2	7.62	—	—	—	—	—	—	
10	晴	5.8	15.1	0.3	7.59	—	—	—	—	—	—	
11	晴	7.3	15.0	0.2	7.61	—	—	—	—	—	—	
12	晴	5.1	14.9	0.3	7.61	—	—	—	—	—	—	
13	曇	5.8	14.5	0.2	7.61	—	—	—	—	—	—	
14	晴	8.0	14.5	0.2	7.67	—	—	—	—	—	—	
15	晴	5.9	14.3	0.2	7.60	—	—	—	—	—	—	
16	晴	5.3	14.1	0.1	7.66	—	—	—	—	—	—	
17	晴	6.1	14.1	0.2	7.62	36.8	38.7	66	7.1	<0.03	<0.02	
18	晴	5.5	14.0	0.2	7.62	—	—	—	—	—	—	
19	晴	4.8	13.7	0.2	7.61	—	—	—	—	—	—	
20	晴	4.5	13.5	0.2	7.62	—	—	—	—	—	—	
21	曇	9.4	13.5	0.2	7.68	—	—	—	—	—	—	
22	晴	6.6	13.3	0.1	7.63	—	—	—	—	—	—	
23	晴	2.7	13.0	0.1	7.74	—	—	—	—	—	—	
24	晴	4.8	12.8	0.2	7.64	—	—	—	—	—	—	
25	晴	3.8	12.6	0.2	7.64	—	—	—	—	—	—	
26	曇	9.6	13.0	0.2	7.66	—	—	—	—	—	—	
27	晴	6.9	13.0	0.4	7.66	—	—	—	—	—	—	
28	晴	6.8	12.8	0.2	7.71	—	—	—	—	—	—	
29	晴	5.0	12.6	<0.1	7.65	—	—	—	—	—	—	
30	晴	2.8	12.4	0.4	7.62	—	—	—	—	—	—	
31	曇	7.9	12.4	0.2	7.57	—	—	—	—	—	—	
平均		6.9	14.4	0.2	7.62	36.2	39.2	62	7.6	<0.03	<0.02	
最高		12.8	16.8	0.5	7.74	36.8	39.7	66	8.0	<0.03	<0.02	
最低		2.7	12.4	<0.1	7.53	35.5	38.7	58	7.1	<0.03	<0.02	