

令和7年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	6.2	10.5	2.3	7.70	—	—	—	—	—	—	
2	晴	8.7	10.4	2.3	7.72	—	—	—	—	—	—	
3	晴	6.2	10.5	2.1	7.69	—	—	—	—	—	—	
4	晴	4.8	10.3	2.0	7.74	—	—	—	—	—	—	
5	晴	8.0	10.1	2.0	7.71	—	—	—	—	—	—	
6	雨	7.8	10.2	2.2	7.70	—	—	—	—	—	—	
7	晴	8.1	10.3	2.1	7.69	40.7	39.9	52	5.3	0.12	<0.02	
8	晴	3.1	10.0	2.0	7.69	—	—	—	—	—	—	
9	晴	2.5	9.7	1.8	7.69	—	—	—	—	—	—	
10	晴	-0.1	9.4	2.0	7.70	—	—	—	—	—	—	
11	晴	3.3	9.5	2.0	7.79	—	—	—	—	—	—	
12	曇	6.3	9.5	1.8	7.69	—	—	—	—	—	—	
13	晴	5.0	9.8	1.8	7.67	—	—	—	—	—	—	
14	晴	4.6	9.4	2.0	7.67	—	—	—	—	—	—	
15	曇	5.9	9.5	1.7	7.64	—	—	—	—	—	—	
16	晴	1.7	9.2	1.9	7.67	—	—	—	—	—	—	
17	晴	3.6	9.1	1.9	7.64	—	—	—	—	—	—	
18	曇	6.0	9.1	1.8	7.64	—	—	—	—	—	—	
19	曇	8.0	9.3	1.8	7.63	—	—	—	—	—	—	
20	晴	6.6	9.4	1.8	7.61	—	—	—	—	—	—	
21	晴	5.5	9.4	2.2	7.60	37.8	42.1	84	5.7	0.11	<0.02	
22	晴	5.4	9.5	2.1	7.60	—	—	—	—	—	—	
23	晴	5.4	9.4	1.8	7.57	—	—	—	—	—	—	
24	晴	5.3	9.4	2.0	7.60	—	—	—	—	—	—	
25	晴	7.1	9.4	2.1	7.55	—	—	—	—	—	—	
26	晴	7.3	9.3	2.0	7.53	—	—	—	—	—	—	
27	曇	5.6	9.2	1.9	7.55	—	—	—	—	—	—	
28	晴	7.4	9.3	2.0	7.55	—	—	—	—	—	—	
29	晴	3.9	9.1	2.0	7.56	—	—	—	—	—	—	
30	晴	3.5	8.9	1.4	7.54	—	—	—	—	—	—	
31	晴	4.3	8.8	1.9	7.55	—	—	—	—	—	—	
平均		5.4	9.6	2.0	7.64	39.2	41.0	68	5.5	0.12	<0.02	
最高		8.7	10.5	2.3	7.79	40.7	42.1	84	5.7	0.12	<0.02	
最低		-0.1	8.8	1.4	7.53	37.8	39.9	52	5.3	0.11	<0.02	

令和7年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	6.2	12.4	0.2	7.60	—	—	—	—	—	—	
2	晴	8.7	12.3	0.1	7.62	—	—	—	—	—	—	
3	晴	6.2	12.3	0.2	7.65	—	—	—	—	—	—	
4	晴	4.8	12.1	<0.1	7.68	—	—	—	—	—	—	
5	晴	8.0	11.9	0.1	7.63	—	—	—	—	—	—	
6	雨	7.8	12.0	0.1	7.65	—	—	—	—	—	—	
7	晴	8.1	12.0	0.1	7.59	37.7	40.4	66	9.1	<0.03	<0.02	
8	晴	3.1	11.7	0.2	7.57	—	—	—	—	—	—	
9	晴	2.5	11.3	0.2	7.64	—	—	—	—	—	—	
10	晴	-0.1	11.0	0.2	7.61	—	—	—	—	—	—	
11	晴	3.3	10.9	<0.1	7.69	—	—	—	—	—	—	
12	曇	6.3	11.0	<0.1	7.62	—	—	—	—	—	—	
13	晴	5.0	11.0	0.5	7.61	—	—	—	—	—	—	
14	晴	4.6	11.0	0.6	7.61	—	—	—	—	—	—	
15	曇	5.9	11.1	0.4	7.60	—	—	—	—	—	—	
16	晴	1.7	10.8	0.3	7.61	—	—	—	—	—	—	
17	晴	3.6	10.8	0.2	7.59	—	—	—	—	—	—	
18	曇	6.0	10.5	0.1	7.57	—	—	—	—	—	—	
19	曇	8.0	10.8	<0.1	7.56	—	—	—	—	—	—	
20	晴	6.6	11.0	0.2	7.53	—	—	—	—	—	—	
21	晴	5.5	11.0	0.3	7.50	37.5	42.3	80	8.4	<0.03	<0.02	
22	晴	5.4	11.0	0.3	7.49	—	—	—	—	—	—	
23	晴	5.4	11.0	0.3	7.47	—	—	—	—	—	—	
24	晴	5.3	11.1	0.3	7.48	—	—	—	—	—	—	
25	晴	7.1	11.0	0.2	7.51	—	—	—	—	—	—	
26	晴	7.3	11.0	0.1	7.45	—	—	—	—	—	—	
27	曇	5.6	11.0	0.3	7.46	—	—	—	—	—	—	
28	晴	7.4	11.0	0.2	7.44	—	—	—	—	—	—	
29	晴	3.9	10.8	0.3	7.44	—	—	—	—	—	—	
30	晴	3.5	10.4	0.4	7.45	—	—	—	—	—	—	
31	晴	4.3	10.3	0.2	7.45	—	—	—	—	—	—	
平均		5.4	11.2	0.2	7.56	37.6	41.4	73	8.8	<0.03	<0.02	
最高		8.7	12.4	0.6	7.69	37.7	42.3	80	9.1	<0.03	<0.02	
最低		-0.1	10.3	<0.1	7.44	37.5	40.4	66	8.4	<0.03	<0.02	