

令和7年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	5.6	8.8	2.1	7.60	—	—	—	—	—	—	
2	雨	7.1	9.1	2.5	7.52	—	—	—	—	—	—	
3	曇	7.0	9.1	2.6	7.62	—	—	—	—	—	—	
4	晴	3.8	9.1	3.3	7.58	42.2	40.4	66	6.7	0.21	0.06	
5	晴	0.6	8.8	3.0	7.62	—	—	—	—	—	—	
6	晴	-0.8	8.5	3.8	7.59	—	—	—	—	—	—	
7	晴	0.5	8.4	4.3	7.58	—	—	—	—	—	—	
8	晴	0.5	8.2	4.9	7.58	—	—	—	—	—	—	
9	晴	3.4	8.4	5.4	7.58	—	—	—	—	—	—	
10	晴	2.1	8.4	5.6	7.58	—	—	—	—	—	—	
11	晴	5.6	8.4	6.2	7.58	—	—	—	—	—	—	
12	晴	4.5	8.5	5.3	7.57	—	—	—	—	—	—	
13	晴	8.6	9.0	5.9	7.62	—	—	—	—	—	—	
14	晴	5.5	8.6	5.3	7.63	—	—	—	—	—	—	
15	晴	10.0	8.8	6.2	7.63	—	—	—	—	—	—	
16	晴	9.1	9.3	5.2	7.63	—	—	—	—	—	—	
17	晴	7.7	9.3	7.0	7.60	—	—	—	—	—	—	
18	晴	1.8	8.9	6.5	7.49	46.6	46.1	88	7.9	0.33	0.09	
19	晴	2.0	8.6	7.7	7.65	—	—	—	—	—	—	
20	晴	1.1	8.5	9.0	7.62	—	—	—	—	—	—	
21	曇	0.0	8.3	8.9	7.58	—	—	—	—	—	—	
22	晴	3.9	8.4	8.2	7.73	—	—	—	—	—	—	
23	晴	4.6	8.3	7.9	7.61	—	—	—	—	—	—	
24	晴	3.3	8.4	9.2	7.60	—	—	—	—	—	—	
25	晴	3.6	8.4	8.8	7.63	—	—	—	—	—	—	
26	晴	8.0	8.8	8.4	7.62	—	—	—	—	—	—	
27	晴	7.0	8.9	7.9	7.62	—	—	—	—	—	—	
28	晴	8.8	9.6	6.5	7.62	—	—	—	—	—	—	
平均		4.5	8.7	6.0	7.60	44.4	43.2	77	7.3	0.27	0.08	
最高		10.0	9.6	9.2	7.73	46.6	46.1	88	7.9	0.33	0.09	
最低		-0.8	8.2	2.1	7.49	42.2	40.4	66	6.7	0.21	0.06	

令和7年2月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	5.6	10.3	0.2	7.47	—	—	—	—	—	—	
2	雨	7.1	10.4	0.2	7.40	—	—	—	—	—	—	
3	曇	7.0	10.6	0.3	7.49	—	—	—	—	—	—	
4	晴	3.8	10.6	0.4	7.42	38.6	40.4	67	10.9	<0.03	<0.02	
5	晴	0.6	10.3	0.3	7.46	—	—	—	—	—	—	
6	晴	-0.8	10.0	0.2	7.48	—	—	—	—	—	—	
7	晴	0.5	9.8	0.2	7.47	—	—	—	—	—	—	
8	晴	0.5	9.7	0.3	7.53	—	—	—	—	—	—	
9	晴	3.4	9.6	0.3	7.45	—	—	—	—	—	—	
10	晴	2.1	9.8	0.2	7.45	—	—	—	—	—	—	
11	晴	5.6	9.8	0.1	7.46	—	—	—	—	—	—	
12	晴	4.5	9.8	0.3	7.47	—	—	—	—	—	—	
13	晴	8.6	10.2	0.3	7.49	—	—	—	—	—	—	
14	晴	5.5	10.1	0.4	7.52	—	—	—	—	—	—	
15	晴	10.0	10.1	0.2	7.52	—	—	—	—	—	—	
16	晴	9.1	10.6	0.2	7.49	—	—	—	—	—	—	
17	晴	7.7	10.7	0.2	7.48	—	—	—	—	—	—	
18	晴	1.8	10.4	0.3	7.48	44.0	46.6	81	11.0	<0.03	<0.02	
19	晴	2.0	10.1	0.3	7.48	—	—	—	—	—	—	
20	晴	1.1	9.8	0.2	7.52	—	—	—	—	—	—	
21	曇	0.0	9.6	0.3	7.48	—	—	—	—	—	—	
22	晴	3.9	9.8	0.3	7.53	—	—	—	—	—	—	
23	晴	4.6	9.6	0.3	7.49	—	—	—	—	—	—	
24	晴	3.3	9.6	0.2	7.48	—	—	—	—	—	—	
25	晴	3.6	9.6	0.4	7.51	—	—	—	—	—	—	
26	晴	8.0	10.0	0.3	7.49	—	—	—	—	—	—	
27	晴	7.0	10.1	0.4	7.49	—	—	—	—	—	—	
28	晴	8.8	10.3	0.6	7.48	—	—	—	—	—	—	
平均		4.5	10.0	0.3	7.48	41.3	43.5	74	11.0	<0.03	<0.02	
最高		10.0	10.7	0.6	7.53	44.0	46.6	81	11.0	<0.03	<0.02	
最低		-0.8	9.6	0.1	7.40	38.6	40.4	67	10.9	<0.03	<0.02	