

令和8年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	6.2	11.1	2.4	7.62	—	—	—	—	—	—	
2	晴	2.9	11.0	2.4	7.60	—	—	—	—	—	—	
3	晴	3.3	10.3	3.2	7.62	—	—	—	—	—	—	
4	晴	5.0	10.1	3.0	7.62	—	—	—	—	—	—	
5	晴	6.4	10.1	2.8	7.60	—	—	—	—	—	—	
6	晴	5.3	10.1	2.8	7.63	44.7	48.2	70	6.2	0.17	0.03	
7	雨	5.4	9.9	2.6	7.59	—	—	—	—	—	—	
8	晴	5.1	9.8	2.6	7.60	—	—	—	—	—	—	
9	晴	1.8	9.5	2.4	7.59	—	—	—	—	—	—	
10	晴	4.4	9.5	3.1	7.63	—	—	—	—	—	—	
11	曇	9.6	9.8	3.2	7.64	—	—	—	—	—	—	
12	晴	0.8	9.2	2.6	7.61	—	—	—	—	—	—	
13	晴	5.1	9.1	2.6	7.62	—	—	—	—	—	—	
14	晴	5.0	9.3	2.4	7.61	—	—	—	—	—	—	
15	晴	4.6	9.2	2.0	7.62	—	—	—	—	—	—	
16	晴	9.5	9.5	2.0	7.60	—	—	—	—	—	—	
17	晴	8.3	9.4	2.6	7.65	—	—	—	—	—	—	
18	晴	8.5	9.5	2.2	7.72	—	—	—	—	—	—	
19	晴	6.3	9.5	2.1	7.64	—	—	—	—	—	—	
20	晴	10.3	9.8	2.2	7.62	45.6	49.6	89	6.0	0.13	0.02	
21	晴	1.3	9.3	2.0	7.64	—	—	—	—	—	—	
22	晴	0.7	9.2	2.1	7.62	—	—	—	—	—	—	
23	晴	0.0	8.8	2.2	7.61	—	—	—	—	—	—	
24	晴	2.2	8.7	2.3	7.67	—	—	—	—	—	—	
25	晴	2.6	8.6	2.4	7.54	—	—	—	—	—	—	
26	晴	1.0	8.3	3.0	7.59	—	—	—	—	—	—	
27	晴	4.1	8.5	3.0	7.65	—	—	—	—	—	—	
28	晴	3.4	8.4	2.9	7.68	—	—	—	—	—	—	
29	晴	3.0	8.5	3.5	7.67	—	—	—	—	—	—	
30	晴	1.1	8.4	3.5	7.68	—	—	—	—	—	—	
31	晴	3.3	8.3	3.5	7.71	—	—	—	—	—	—	
平均		4.4	9.4	2.6	7.63	45.2	48.9	80	6.1	0.15	0.02	
最高		10.3	11.1	3.5	7.72	45.6	49.6	89	6.2	0.17	0.03	
最低		0.0	8.3	2.0	7.54	44.7	48.2	70	6.0	0.13	0.02	

令和8年1月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温	水温	濁度	pH	アルカリ度	硬度	蒸発残留物	塩化物イオン	鉄	マンガン	
		℃	℃	度		mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	
1	晴	6.2	13.4	<0.1	7.57	—	—	—	—	—	—	
2	晴	2.9	13.1	0.1	7.53	—	—	—	—	—	—	
3	晴	3.3	12.2	0.2	7.56	—	—	—	—	—	—	
4	晴	5.0	12.1	<0.1	7.52	—	—	—	—	—	—	
5	晴	6.4	12.0	0.1	7.54	—	—	—	—	—	—	
6	晴	5.3	12.0	0.2	7.47	42.7	49.4	68	10.3	<0.03	0.05	
7	雨	5.4	11.7	0.2	7.42	—	—	—	—	—	—	
8	晴	5.1	11.7	0.2	7.45	—	—	—	—	—	—	
9	晴	1.8	11.3	0.1	7.50	—	—	—	—	—	—	
10	晴	4.4	11.1	0.1	7.54	—	—	—	—	—	—	
11	曇	9.6	11.7	<0.1	7.55	—	—	—	—	—	—	
12	晴	0.8	11.0	<0.1	7.50	—	—	—	—	—	—	
13	晴	5.1	10.8	0.1	7.50	—	—	—	—	—	—	
14	晴	5.0	11.0	<0.1	7.49	—	—	—	—	—	—	
15	晴	4.6	11.0	<0.1	7.49	—	—	—	—	—	—	
16	晴	9.5	11.2	0.2	7.52	—	—	—	—	—	—	
17	晴	8.3	11.2	0.2	7.55	—	—	—	—	—	—	
18	晴	8.5	11.5	0.3	7.50	—	—	—	—	—	—	
19	晴	6.3	11.3	<0.1	7.53	—	—	—	—	—	—	
20	晴	10.3	11.6	0.3	7.51	42.7	49.5	82	8.9	0.03	<0.02	
21	晴	1.3	11.1	<0.1	7.51	—	—	—	—	—	—	
22	晴	0.7	10.8	0.2	7.54	—	—	—	—	—	—	
23	晴	0.0	10.5	0.2	7.52	—	—	—	—	—	—	
24	晴	2.2	10.2	<0.1	7.55	—	—	—	—	—	—	
25	晴	2.6	10.3	<0.1	7.36	—	—	—	—	—	—	
26	晴	1.0	10.0	0.3	7.44	—	—	—	—	—	—	
27	晴	4.1	10.0	0.2	7.59	—	—	—	—	—	—	
28	晴	3.4	10.1	0.2	7.59	—	—	—	—	—	—	
29	晴	3.0	10.1	<0.1	7.57	—	—	—	—	—	—	
30	晴	1.1	9.8	0.3	7.59	—	—	—	—	—	—	
31	晴	3.3	9.8	0.1	7.62	—	—	—	—	—	—	
平均		4.4	11.1	0.1	7.52	42.7	49.4	75	9.6	<0.03	0.02	
最高		10.3	13.4	0.3	7.62	42.7	49.5	82	10.3	0.03	0.05	
最低		0.0	9.8	<0.1	7.36	42.7	49.4	68	8.9	<0.03	<0.02	