

令和8年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	12.8	10.6	3.0	7.62	—	—	—	—	—	—	
2	晴	14.2	11.1	2.9	7.60	—	—	—	—	—	—	
3	雨	10.6	9.7	2.6	7.69	45.6	48.9	86	8.4	0.22	0.04	
4	晴	10.7	9.7	3.8	7.72	—	—	—	—	—	—	
5	晴	7.7	9.3	3.4	7.75	—	—	—	—	—	—	
6	曇	10.1	9.8	3.8	7.69	—	—	—	—	—	—	
7	晴	10.7	12.1	2.4	7.60	—	—	—	—	—	—	
8	晴	8.1	11.7	2.1	7.62	—	—	—	—	—	—	
9	晴	5.5	11.6	2.0	7.61	—	—	—	—	—	—	
10	晴	6.9	11.3	2.5	7.62	—	—	—	—	—	—	
11	曇	7.5	11.4	2.2	7.58	—	—	—	—	—	—	
12	晴	6.5	11.2	2.3	7.62	—	—	—	—	—	—	
13	曇	7.7	11.3	2.1	7.57	—	—	—	—	—	—	
14	晴	10.4	11.2	2.2	7.60	—	—	—	—	—	—	
15	晴	10.8	11.4	2.5	7.61	—	—	—	—	—	—	
16	晴	8.5	11.5	2.2	7.55	—	—	—	—	—	—	
17	曇	11.2	11.7	2.1	7.54	41.6	48.6	68	7.2	0.10	<0.02	
18	曇	10.7	11.8	2.0	7.63	—	—	—	—	—	—	
19	曇	12.9	12.2	1.7	7.60	—	—	—	—	—	—	
20	曇	12.3	12.5	1.8	7.62	—	—	—	—	—	—	
21	晴	9.5	12.2	1.7	7.66	—	—	—	—	—	—	
22	晴	11.5	12.4	1.8	7.62	—	—	—	—	—	—	
23	曇	11.0	12.6	1.7	7.60	—	—	—	—	—	—	
24	晴	13.0	12.6	1.4	7.60	—	—	—	—	—	—	
25	雨	13.5	12.7	1.4	7.64	—	—	—	—	—	—	
26	雨	11.8	12.8	1.1	7.57	—	—	—	—	—	—	
27	晴	12.6	12.9	1.2	7.59	—	—	—	—	—	—	
28	晴	14.5	12.9	1.4	7.61	—	—	—	—	—	—	
29	晴	15.2	13.3	1.5	7.65	—	—	—	—	—	—	
30	曇	16.3	13.6	1.2	7.64	—	—	—	—	—	—	
31	雨	15.1	14.0	1.3	7.58	—	—	—	—	—	—	
平均		11.0	11.8	2.1	7.62	43.6	48.8	77	7.8	0.16	0.02	
最高		16.3	14.0	3.8	7.75	45.6	48.9	86	8.4	0.22	0.04	
最低		5.5	9.3	1.1	7.54	41.6	48.6	68	7.2	0.10	<0.02	

令和8年3月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	12.8	12.1	0.5	7.52	—	—	—	—	—	—	
2	晴	14.2	12.5	0.5	7.48	—	—	—	—	—	—	
3	雨	10.6	11.7	<0.1	7.44	40.1	49.0	87	12.9	<0.03	<0.02	
4	晴	10.7	12.5	<0.1	7.48	—	—	—	—	—	—	
5	晴	7.7	11.2	<0.1	7.55	—	—	—	—	—	—	
6	曇	10.1	11.4	0.1	7.53	—	—	—	—	—	—	
7	晴	10.7	12.6	0.1	7.54	—	—	—	—	—	—	
8	晴	8.1	12.3	0.3	7.54	—	—	—	—	—	—	
9	晴	5.5	12.0	0.3	7.54	—	—	—	—	—	—	
10	晴	6.9	12.0	0.2	7.52	—	—	—	—	—	—	
11	曇	7.5	12.1	0.2	7.47	—	—	—	—	—	—	
12	晴	6.5	12.0	0.3	7.52	—	—	—	—	—	—	
13	曇	7.7	12.1	0.2	7.45	—	—	—	—	—	—	
14	晴	10.4	12.0	0.2	7.52	—	—	—	—	—	—	
15	晴	10.8	12.2	0.3	7.51	—	—	—	—	—	—	
16	晴	8.5	12.3	0.2	7.50	—	—	—	—	—	—	
17	曇	11.2	12.5	0.2	7.47	40.5	48.3	74	10.2	<0.03	<0.02	
18	曇	10.7	12.6	<0.1	7.55	—	—	—	—	—	—	
19	曇	12.9	13.0	0.2	7.52	—	—	—	—	—	—	
20	曇	12.3	13.0	0.2	7.55	—	—	—	—	—	—	
21	晴	9.5	13.0	0.2	7.58	—	—	—	—	—	—	
22	晴	11.5	13.1	0.2	7.56	—	—	—	—	—	—	
23	曇	11.0	13.1	0.1	7.55	—	—	—	—	—	—	
24	晴	13.0	13.3	0.2	7.57	—	—	—	—	—	—	
25	雨	13.5	13.6	0.2	7.56	—	—	—	—	—	—	
26	雨	11.8	13.3	0.2	7.56	—	—	—	—	—	—	
27	晴	12.6	13.6	0.1	7.52	—	—	—	—	—	—	
28	晴	14.5	13.6	0.2	7.55	—	—	—	—	—	—	
29	晴	15.2	13.9	0.2	7.55	—	—	—	—	—	—	
30	曇	16.3	14.3	0.2	7.57	—	—	—	—	—	—	
31	雨	15.1	14.5	0.2	7.50	—	—	—	—	—	—	
平均		11.0	12.7	0.2	7.52	40.3	48.6	80	11.6	<0.03	<0.02	
最高		16.3	14.5	0.5	7.58	40.5	49.0	87	12.9	<0.03	<0.02	
最低		5.5	11.2	<0.1	7.44	40.1	48.3	74	10.2	<0.03	<0.02	