

令和8年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(着水井(原水))											備考
	天候	気温	水温	濁度	pH	アルカリ度	硬度	蒸発残留物	塩化物イオン	鉄	マンガン	
		℃	℃	度		mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	
1	晴	31.8	26.2	3.0	7.70	—	—	—	—	—	—	
2	晴	32.8	26.5	2.8	7.64	—	—	—	—	—	—	
3	曇	30.1	26.6	5.0	7.64	—	—	—	—	—	—	
4	曇	27.0	26.3	3.5	7.59	42.5	45.2	70	3.8	0.13	<0.02	
5	晴	28.5	26.2	3.0	7.55	—	—	—	—	—	—	
6	晴	31.5	26.5	2.6	7.63	—	—	—	—	—	—	
7	晴	30.0	26.7	2.9	7.64	—	—	—	—	—	—	
8	晴	31.0	26.8	3.1	7.65	—	—	—	—	—	—	
9	曇	30.1	26.7	3.0	7.62	—	—	—	—	—	—	
10	曇	29.3	26.7	3.4	7.62	—	—	—	—	—	—	
11	曇	25.8	26.4	3.3	7.55	—	—	—	—	—	—	
12	晴	27.9	26.5	3.0	7.58	—	—	—	—	—	—	
13	曇	26.6	26.3	3.0	7.59	—	—	—	—	—	—	
14	晴	28.0	26.3	3.1	7.61	—	—	—	—	—	—	
15	曇	29.0	26.3	4.4	7.60	—	—	—	—	—	—	
16	晴	28.8	26.3	3.8	7.65	—	—	—	—	—	—	
17	曇	28.4	26.4	4.0	7.63	—	—	—	—	—	—	
18	晴	28.3	26.4	3.7	7.66	41.6	40.7	66	4.0	0.17	<0.02	
19	晴	28.3	26.3	3.9	7.63	—	—	—	—	—	—	
20	曇	27.1	26.5	5.7	7.69	—	—	—	—	—	—	
21	晴	28.8	26.4	3.4	7.67	—	—	—	—	—	—	
22	晴	29.7	26.5	3.1	7.61	—	—	—	—	—	—	
23	晴	28.9	26.6	3.3	7.61	—	—	—	—	—	—	
24	晴	28.4	26.6	3.3	7.57	—	—	—	—	—	—	
25	曇	29.3	26.7	3.6	7.38	—	—	—	—	—	—	
26	晴	29.0	26.8	3.9	7.59	—	—	—	—	—	—	
27	曇	30.4	27.0	4.4	7.63	—	—	—	—	—	—	
28	曇	25.7	26.8	4.1	7.61	—	—	—	—	—	—	
29	曇	27.7	26.6	4.3	7.59	—	—	—	—	—	—	
30	晴	29.8	26.6	4.0	7.60	—	—	—	—	—	—	
31	曇	29.1	26.7	4.9	7.59	—	—	—	—	—	—	
平均		28.9	26.5	3.6	7.61	42.0	43.0	68	3.9	0.15	<0.02	
最高		32.8	27.0	5.7	7.70	42.5	45.2	70	4.0	0.17	<0.02	
最低		25.7	26.2	2.6	7.38	41.6	40.7	66	3.8	0.13	<0.02	

令和8年8月分

中遠工業用水道水質試験結果報告書

採水時間 9:00

日	水質試験結果(配水池(浄水))											備考
	天候	気温	水温	濁度	pH	アルカリ度	硬度	蒸発残留物	塩化物イオン	鉄	マンガン	
		℃	℃	度		mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	
1	晴	31.8	28.1	0.1	7.64	—	—	—	—	—	—	
2	晴	32.8	28.7	0.1	7.66	—	—	—	—	—	—	
3	曇	30.1	28.6	0.2	7.69	—	—	—	—	—	—	
4	曇	27.0	28.0	0.2	7.57	39.6	45.0	79	6.8	<0.03	<0.02	
5	晴	28.5	28.3	0.1	7.57	—	—	—	—	—	—	
6	晴	31.5	28.4	0.2	7.61	—	—	—	—	—	—	
7	晴	30.0	28.5	0.3	7.66	—	—	—	—	—	—	
8	晴	31.0	28.9	0.2	7.62	—	—	—	—	—	—	
9	曇	30.1	29.0	0.3	7.62	—	—	—	—	—	—	
10	曇	29.3	28.9	0.2	7.65	—	—	—	—	—	—	
11	曇	25.8	28.3	0.2	7.62	—	—	—	—	—	—	
12	晴	27.9	28.0	0.2	7.64	—	—	—	—	—	—	
13	曇	26.6	27.8	0.2	7.69	—	—	—	—	—	—	
14	晴	28.0	28.3	0.3	7.69	—	—	—	—	—	—	
15	曇	29.0	28.1	0.2	7.61	—	—	—	—	—	—	
16	晴	28.8	28.0	0.2	7.67	—	—	—	—	—	—	
17	曇	28.4	28.3	0.2	7.63	—	—	—	—	—	—	
18	晴	28.3	28.2	0.2	7.63	40.0	41.8	71	7.0	<0.03	<0.02	
19	晴	28.3	28.4	0.2	7.68	—	—	—	—	—	—	
20	曇	27.1	28.0	0.2	7.69	—	—	—	—	—	—	
21	晴	28.8	28.2	0.2	7.65	—	—	—	—	—	—	
22	晴	29.7	28.3	0.1	7.59	—	—	—	—	—	—	
23	晴	28.9	28.4	0.3	7.60	—	—	—	—	—	—	
24	晴	28.4	28.6	0.2	7.59	—	—	—	—	—	—	
25	曇	29.3	28.3	0.2	7.57	—	—	—	—	—	—	
26	晴	29.0	28.6	0.2	7.59	—	—	—	—	—	—	
27	曇	30.4	28.7	0.2	7.59	—	—	—	—	—	—	
28	曇	25.7	28.0	0.2	7.61	—	—	—	—	—	—	
29	曇	27.7	28.0	0.1	7.55	—	—	—	—	—	—	
30	晴	29.8	28.0	0.2	7.59	—	—	—	—	—	—	
31	曇	29.1	28.0	0.1	7.57	—	—	—	—	—	—	
平均		28.9	28.3	0.2	7.62	39.8	43.4	75	6.9	<0.03	<0.02	
最高		32.8	29.0	0.3	7.69	40.0	45.0	79	7.0	<0.03	<0.02	
最低		25.7	27.8	0.1	7.55	39.6	41.8	71	6.8	<0.03	<0.02	