

様式－工水1 (A4用紙)

令和 4年 1月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	4.3	6.5	0.4	7.36							
2	晴	4.2	6.4	0.4	7.38							
3	晴	6.3	6.5	0.4	7.31							
4	晴	6.1	6.4	0.4	7.36							
5	晴	3.0	5.9	0.4	7.34							
6	雨	2.9	5.8	0.4	7.28	14.6	19.2	85	5.7	0.05	<0.02	
7	晴	3.8	5.9	0.4	7.28							
8	晴	5.4	5.9	0.4	7.27							
9	晴	9.4	5.9	0.4	7.26							
10	晴	10.3	6.0	0.5	7.28							
11	雨	7.8	6.2	0.5	7.31							
12	晴	2.1	6.3	0.5	7.29							
13	晴	3.0	6.1	0.5	7.30							
14	曇	0.2	6.1	0.6	7.29							
15	曇	3.4	5.5	0.5	7.29							
16	晴	7.5	5.5	0.4	7.38							
17	晴	5.1	5.6	0.4	7.39							
18	雪	1.0	5.5	0.4	7.36							
19	晴	1.0	5.5	0.6	7.40							
20	晴	3.5	5.5	0.7	7.34	16.1	20.4	35	4.6	0.04	<0.02	
21	晴	1.8	5.4	0.6	7.40							
22	晴	4.0	5.2	0.6	7.40							
23	曇	5.2	5.1	0.5	7.38							
24	曇	4.1	5.0	0.6	7.37							
25	曇	4.8	5.3	0.6	7.37							
26	晴	6.0	5.4	0.4	7.35							
27	曇	4.7	5.8	0.4	7.32							
28	晴	3.0	5.9	0.4	7.31							
29	曇	6.6	6.1	0.7	7.32							
30	晴	6.0	6.1	0.4	7.31							
31	晴	4.0	5.9	0.4	7.30							
平均		4.5	5.8	0.5	7.33	15.4	19.8	60	5.2	0.04	<0.02	
最高		10.3	6.5	0.7	7.40	16.1	20.4	85	5.7	0.05	<0.02	
最低		0.2	5.0	0.4	7.26	14.6	19.2	35	4.6	0.04	<0.02	

様式一工水1 (A4用紙)

令和 4年 1月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 °C	淨 水 水質試験結果 (配水池)								備考
			水温 °C	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	
1	晴	4.3	6.9	0.3	7.42						
2	晴	4.2	6.5	0.4	7.44						
3	晴	6.3	6.4	0.3	7.41						
4	晴	6.1	6.5	0.3	7.42						
5	晴	3.0	6.4	0.3	7.40						
6	雨	2.9	6.1	0.3	7.34	14.8	18.9	79	5.6	0.05	<0.02
7	晴	3.8	5.9	0.3	7.34						
8	晴	5.4	5.8	0.3	7.36						
9	晴	9.4	5.9	0.4	7.32						
10	晴	10.3	6.0	0.4	7.33						
11	雨	7.8	6.2	0.3	7.35						
12	晴	2.1	6.2	0.4	7.35						
13	晴	3.0	6.1	0.4	7.31						
14	曇	0.2	6.1	0.4	7.34						
15	曇	3.4	5.9	0.4	7.37						
16	晴	7.5	5.6	0.4	7.41						
17	晴	5.1	5.6	0.4	7.42						
18	雪	1.0	5.5	0.4	7.38						
19	晴	1.0	5.4	0.5	7.41						
20	晴	3.5	5.5	0.6	7.40	16.5	20.5	39	4.6	0.06	<0.02
21	晴	1.8	5.4	0.5	7.45						
22	晴	4.0	5.3	0.5	7.44						
23	曇	5.2	5.2	0.4	7.46						
24	曇	4.1	5.2	0.5	7.45						
25	曇	4.8	5.4	0.5	7.44						
26	晴	6.0	5.5	0.4	7.45						
27	曇	4.7	5.6	0.4	7.32						
28	晴	3.0	5.7	0.4	7.31						
29	曇	6.6	5.9	0.4	7.33						
30	晴	6.0	6.0	0.4	7.36						
31	晴	4.0	5.9	0.4	7.38						
平均		4.5	5.9	0.4	7.38	15.6	19.7	59	5.1	0.06	<0.02
最高		10.3	6.9	0.6	7.46	16.5	20.5	79	5.6	0.06	<0.02
最低		0.2	5.2	0.3	7.31	14.8	18.9	39	4.6	0.05	<0.02