

令和 4年 10月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	26.8	20.9	0.4	7.47							
2	晴	26.7	20.9	0.4	7.55							
3	曇	24.2	20.7	0.4	7.62							
4	曇	25.9	20.6	0.3	7.51							
5	曇	23.2	20.5	0.3	7.59							
6	雨	16.7	20.2	0.3	7.57	21.2	21.0	49.0	3.1	0.04	<0.02	
7	曇	16.0	20.1	0.3	7.60							
8	曇	17.8	19.7	0.3	7.54							
9	曇	18.5	19.2	0.1	7.43							
10	雨	19.4	18.8	0.3	7.50							
11	晴	18.1	18.1	0.3	7.47							
12	曇	16.5	18.1	0.4	7.41							
13	曇	18.0	18.2	0.6	7.43							
14	晴	22.8	18.3	0.4	7.40							
15	晴	24.8	17.9	0.3	7.39							
16	晴	25.5	18.0	0.4	7.46							
17	雨	22.7	18.0	0.3	7.47							
18	曇	16.2	18.3	0.2	7.54							
19	晴	18.7	18.5	0.2	7.50							
20	晴	18.0	18.6	0.2	7.53	21.8	22.5	55.0	3.6	<0.03	<0.02	
21	晴	19.8	18.2	0.2	7.52							
22	曇	18.4	17.1	0.5	7.40							
23	晴	20.9	17.0	0.4	7.38							
24	晴	17.2	16.9	0.4	7.41							
25	曇	25.0	16.9	0.4	7.42							
26	晴	16.0	16.5	0.4	7.44							
27	曇	15.0	16.2	0.4	7.36							
28	曇	16.5	15.7	0.4	7.38							
29	晴	17.5	15.5	0.3	7.32							
30	曇	15.2	15.6	0.4	7.36							
31	晴	17.2	15.8	0.3	7.41							
平均		19.8	18.2	0.3	7.46	21.5	21.8	52	3.4	<0.03	<0.02	
最高		26.8	20.9	0.6	7.62	21.8	22.5	55	3.6	0.04	<0.02	
最低		15.0	15.5	0.1	7.32	21.2	21.0	49	3.1	<0.03	<0.02	

令和 4年 10月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	26.8	21.6	0.4	7.50							
2	晴	26.7	21.6	0.3	7.60							
3	曇	24.2	21.4	0.3	7.63							
4	曇	25.9	21.4	0.3	7.56							
5	曇	23.2	21.4	0.3	7.61							
6	雨	16.7	21.0	0.3	7.63	21.0	21.0	49.0	3.1	<0.03	<0.02	
7	曇	16.0	20.7	0.2	7.65							
8	曇	17.8	20.3	0.2	7.63							
9	曇	18.5	20.0	0.1	7.59							
10	雨	19.4	19.6	0.2	7.57							
11	晴	18.1	19.0	0.2	7.57							
12	曇	16.5	18.7	0.2	7.53							
13	曇	18.0	18.6	0.4	7.53							
14	晴	22.8	18.7	0.4	7.45							
15	晴	24.8	18.8	0.3	7.43							
16	晴	25.5	18.7	0.4	7.48							
17	雨	22.7	18.8	0.3	7.51							
18	曇	16.2	18.7	0.2	7.56							
19	晴	18.7	18.8	0.2	7.56							
20	晴	18.0	18.9	0.2	7.59	21.2	22.2	60.0	3.4	<0.03	<0.02	
21	晴	19.8	18.8	0.2	7.60							
22	曇	18.4	18.3	0.4	7.55							
23	晴	20.9	17.9	0.3	7.50							
24	晴	17.2	17.6	0.3	7.51							
25	曇	25.0	17.5	0.3	7.50							
26	晴	16.0	17.2	0.3	7.48							
27	曇	15.0	16.8	0.3	7.47							
28	曇	16.5	16.5	0.3	7.38							
29	晴	17.5	16.1	0.3	7.39							
30	曇	15.2	15.9	0.3	7.40							
31	晴	17.2	16.1	0.3	7.44							
平均		19.8	18.9	0.3	7.53	21.1	21.6	54	3.2	<0.03	<0.02	
最高		26.8	21.6	0.4	7.65	21.2	22.2	60	3.4	<0.03	<0.02	
最低		15.0	15.9	0.1	7.38	21.0	21.0	49	3.1	<0.03	<0.02	