

令和 5年 7月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考	
			水温 ℃	濁度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸 発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l		
1	雨	25.6	20.1	0.8	7.19								
2	晴	27.0	20.9	1.0	7.34								
3	晴	30.0	21.7	1.8	7.56								
4	晴	28.8	20.5	1.3	7.16								
5	曇	22.5	21.4	0.8	7.25								
6	晴	26.0	21.7	0.7	7.29	18.7	17.7	61	2.6	0.03	<0.02		
7	晴	28.3	21.2	0.8	7.18								
8	曇	27.0	20.8	0.8	7.17								
9	曇	27.4	21.8	0.7	7.24								
10	晴	31.5	21.8	0.8	7.17								
11	晴	31.5	21.1	0.8	7.14								
12	晴	32.0	22.9	0.8	7.66								
13	曇	26.0	22.5	1.3	7.53								
14	晴	27.8	22.1	2.7	7.38								
15	曇	27.8	21.7	3.9	7.21								
16	晴	29.4	22.5	1.8	7.43								
17	晴	31.7	22.7	1.4	7.58								
18	晴	31.0	23.4	1.4	7.54								
19	晴	30.0	17.1	1.6	7.45								
20	晴	29.5	22.4	5.0	7.45	20.0	20.6	44	2.4	<0.03	<0.02		
21	曇	27.9	22.1	5.1	7.57								
22	晴	29.8	20.8	7.4	7.45								
23	晴	30.0	21.4	5.2	7.29								
24	晴	30.2	21.4	4.4	7.20								
25	晴	30.7	21.3	6.0	7.24								
26	晴	32.0	21.5	13.0	7.52								
27	晴	32.1	21.7	13.0	7.62								
28	晴	32.0	22.5	11.3	7.66								
29	晴	31.6	22.6	9.6	7.61								
30	晴	33.1	21.9	4.1	7.37								
31	晴	31.3	21.8	3.2	7.34								
平均		29.4	21.6	3.6	7.38	19.4	19.2	52	2.5	<0.03	<0.02		
最高		33.1	23.4	13.0	7.66	20.0	20.6	61	2.6	0.03	<0.02		
最低		22.5	17.1	0.7	7.14	18.7	17.7	44	2.4	<0.03	<0.02		

令和 5年 7月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果（配水池）									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l		
1	雨	25.6	21.4	0.8	7.27								
2	晴	27.0	21.5	0.6	7.33								
3	晴	30.0	21.8	1.1	7.32								
4	晴	28.8	22.0	1.4	7.27								
5	曇	22.5	22.3	1.0	7.36								
6	晴	26.0	22.6	0.6	7.43	17.1	16.3	66	2.3	<0.03	<0.02		
7	晴	28.3	22.6	0.6	7.38								
8	曇	27.0	22.5	0.6	7.30								
9	曇	27.4	22.6	0.6	7.39								
10	晴	31.5	22.7	0.6	7.31								
11	晴	31.5	22.7	0.6	7.31								
12	晴	32.0	22.8	0.6	7.30								
13	曇	26.0	23.1	0.8	7.30								
14	晴	27.8	22.6	1.2	7.31								
15	曇	27.8	22.5	2.8	7.01								
16	晴	29.4	22.6	1.9	7.21								
17	晴	31.7	22.9	1.2	7.34								
18	晴	31.0	23.4	1.0	7.36								
19	晴	30.0	23.8	1.0	7.28								
20	晴	29.5	23.8	2.3	7.32	16.9	18.5	46	2.3	<0.03	<0.02		
21	曇	27.9	23.0	1.6	7.07								
22	晴	29.8	22.8	0.7	7.00								
23	晴	30.0	22.7	1.9	7.18								
24	晴	30.2	23.1	0.8	6.71								
25	晴	30.7	23.5	2.9	7.17								
26	晴	32.0	23.5	0.8	7.02								
27	晴	32.1	23.7	0.6	7.12								
28	晴	32.0	24.0	0.6	7.17								
29	晴	31.6	24.2	0.7	7.22								
30	晴	33.1	24.1	1.1	7.18								
31	晴	31.3	24.0	2.4	7.43								
平均		29.4	22.9	1.1	7.24	17.0	17.4	56	2.3	<0.03	<0.02		
最高		33.1	24.2	2.9	7.43	17.1	18.5	66	2.3	<0.03	<0.02		
最低		22.5	21.4	0.6	6.71	16.9	16.3	46	2.3	<0.03	<0.02		