

令和 6年 11月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	20.3	18.7	0.7	7.10							
2	雨	20.0	18.2	0.6	7.21							
3	晴	19.6	18.4	0.8	7.14							
4	晴	20.2	18.6	2.7	7.11							
5	曇	17.8	18.6	1.2	7.14							
6	晴	18.7	18.0	0.8	7.22							
7	晴	15.0	17.6	0.7	7.23	15.4	16.2	61	2.3	<0.03	<0.02	
8	晴	12.1	16.7	0.6	7.27							
9	晴	15.8	16.4	0.6	7.34							
10	曇	15.8	15.5	0.5	7.32							
11	晴	16.7	15.0	0.4	7.43							
12	曇	19.5	15.0	0.4	7.35							
13	晴	19.7	15.5	0.9	7.44							
14	曇	16.6	16.0	0.7	7.48							
15	曇	16.4	16.1	0.6	7.46							
16	曇	17.5	16.0	0.2	7.55							
17	晴	20.1	15.9	0.2	7.46							
18	晴	17.2	16.4	0.3	7.50							
19	晴	7.2	15.5	0.2	7.51							
20	晴	10.0	15.5	0.2	7.52							
21	晴	13.3	15.0	0.1	7.35	22.4	22.7	77	4.0	<0.03	<0.02	
22	晴	14.1	14.3	0.1	7.38							
23	晴	11.5	13.9	0.1	7.41							
24	晴	10.0	13.5	0.1	7.37							
25	晴	10.0	13.3	0.1	7.37							
26	曇	13.7	13.0	0.1	7.36							
27	晴	12.5	13.2	0.2	7.33							
28	晴	11.3	13.3	0.8	7.32							
29	晴	9.5	13.1	1.0	7.25							
30	晴	10.0	12.7	0.5	7.24							
平均		15.1	15.6	0.5	7.34	18.9	19.4	69	3.2	<0.03	<0.02	
最高		20.3	18.7	2.7	7.55	22.4	22.7	77	4.0	<0.03	<0.02	
最低		7.2	12.7	0.1	7.10	15.4	16.2	61	2.3	<0.03	<0.02	

令和 6年 11月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	曇	20.3	18.8	0.8	7.13							
2	雨	20.0	18.8	0.7	7.10							
3	晴	19.6	18.6	0.7	7.13							
4	晴	20.2	18.7	1.1	7.11							
5	曇	17.8	18.8	1.7	7.07							
6	晴	18.7	18.5	1.1	7.10							
7	晴	15.0	18.2	0.9	7.16	14.6	15.4	58	2.1	0.03	<0.02	
8	晴	12.1	17.3	0.5	7.23							
9	晴	15.8	16.8	0.5	7.25							
10	曇	15.8	16.4	0.4	7.31							
11	晴	16.7	15.9	0.4	7.31							
12	曇	19.5	15.7	0.4	7.35							
13	晴	19.7	15.7	0.5	7.39							
14	曇	16.6	16.1	0.5	7.41							
15	曇	16.4	16.4	0.4	7.41							
16	曇	17.5	16.4	0.3	7.47							
17	晴	20.1	16.2	0.2	7.43							
18	晴	17.2	16.5	0.2	7.43							
19	晴	7.2	16.0	0.2	7.45							
20	晴	10.0	15.6	0.2	7.47							
21	晴	13.3	15.5	0.2	7.42	22.3	23.0	69	4.3	<0.03	<0.02	
22	晴	14.1	14.9	0.2	7.35							
23	晴	11.5	14.4	0.2	7.39							
24	晴	10.0	13.9	0.2	7.39							
25	晴	10.0	13.7	0.2	7.39							
26	曇	13.7	13.5	0.2	7.37							
27	晴	12.5	13.4	0.2	7.35							
28	晴	11.3	13.5	0.7	7.34							
29	晴	9.5	13.3	1.4	7.31							
30	晴	10.0	13.1	1.0	7.23							
平均		15.1	16.0	0.5	7.31	18.4	19.2	64	3.2	<0.03	<0.02	
最高		20.3	18.8	1.7	7.47	22.3	23.0	69	4.3	0.03	<0.02	
最低		7.2	13.1	0.2	7.07	14.6	15.4	58	2.1	<0.03	<0.02	