

令和 6年 12月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	11.0	11.8	0.3	7.31							
2	晴	14.0	11.2	0.2	7.34							
3	晴	13.6	10.7	0.1	7.35							
4	晴	12.2	10.7	0.1	7.40							
5	晴	11.2	10.6	0.1	7.43	20.5	23.4	58	4.9	0.04	<0.02	
6	晴	9.8	10.9	0.1	7.39							
7	晴	10.0	11.0	0.5	7.52							
8	晴	7.8	10.9	0.5	7.53							
9	晴	6.9	10.5	0.5	7.53							
10	晴	8.0	10.2	0.5	7.51							
11	晴	9.9	10.2	0.5	7.48							
12	晴	7.1	10.0	0.5	7.55							
13	曇	7.0	9.5	0.5	7.55							
14	晴	7.0	9.9	0.5	7.57							
15	晴	6.2	9.5	0.5	7.49							
16	晴	8.2	9.6	0.5	7.54							
17	晴	7.5	9.6	0.5	7.51							
18	晴	6.8	9.5	0.5	7.53							
19	晴	5.0	9.6	0.5	7.54	17.0	17.8	31	3.4	0.05	<0.02	
20	晴	7.6	9.2	0.5	7.51							
21	曇	7.2	9.0	0.5	7.58							
22	晴	6.0	8.6	0.5	7.55							
23	晴	5.0	8.3	0.5	7.60							
24	晴	6.0	8.3	0.5	7.59							
25	晴	6.0	8.4	0.4	7.57							
26	曇	8.5	8.3	0.5	7.60							
27	晴	8.0	8.8	0.5	7.53							
28	晴	6.0	8.5	0.5	7.52							
29	晴	5.8	8.8	0.4	7.52							
30	晴	3.9	8.8	0.4	7.51							
31	曇	7.5	8.6	0.4	7.50							
平均		8.0	9.7	0.4	7.50	18.8	20.6	44	4.2	0.05	<0.02	
最高		14.0	11.8	0.5	7.60	20.5	23.4	58	4.9	0.05	<0.02	
最低		3.9	8.3	0.1	7.31	17.0	17.8	31	3.4	0.04	<0.02	

令和 6年 12月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考	
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L		
1	晴	11.0	12.5	0.6	7.26								
2	晴	14.0	12.0	0.4	7.32								
3	晴	13.6	11.5	0.3	7.35								
4	晴	12.2	11.3	0.2	7.39								
5	晴	11.2	11.1	0.2	7.43	20.6	22.6	52	4.8	0.04	<0.02		
6	晴	9.8	11.1	0.1	7.45								
7	晴	10.0	11.2	0.5	7.59								
8	晴	7.8	11.1	0.5	7.61								
9	晴	6.9	10.8	0.5	7.59								
10	晴	8.0	10.5	0.5	7.58								
11	晴	9.9	10.4	0.5	7.55								
12	晴	7.1	10.3	0.4	7.53								
13	曇	7.0	9.9	0.4	7.53								
14	晴	7.0	9.8	0.4	7.53								
15	晴	6.2	9.8	0.4	7.52								
16	晴	8.2	9.5	0.4	7.52								
17	晴	7.5	9.7	0.4	7.50								
18	晴	6.8	9.5	0.4	7.50								
19	晴	5.0	9.5	0.4	7.51	17.0	18.1	31	3.5	0.05	<0.02		
20	晴	7.6	9.3	0.4	7.50								
21	曇	7.2	9.1	0.4	7.51								
22	晴	6.0	8.8	0.4	7.53								
23	晴	5.0	8.5	0.4	7.55								
24	晴	6.0	8.3	0.4	7.57								
25	晴	6.0	8.4	0.4	7.56								
26	曇	8.5	8.5	0.4	7.55								
27	晴	8.0	8.7	0.4	7.55								
28	晴	6.0	8.6	0.4	7.54								
29	晴	5.8	8.6	0.3	7.54								
30	晴	3.9	8.7	0.3	7.53								
31	曇	7.5	8.7	0.3	7.53								
平均		8.0	9.9	0.4	7.51	18.8	20.4	42	4.2	0.05	<0.02		
最高		14.0	12.5	0.6	7.61	20.6	22.6	52	4.8	0.05	<0.02		
最低		3.9	8.3	0.1	7.26	17.0	18.1	31	3.5	0.04	<0.02		