

令和 7年 1月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	5.8	8.5	0.4	7.45							
2	晴	8.1	8.3	0.4	7.42							
3	晴	8.2	8.5	0.4	7.40							
4	晴	5.0	8.5	0.4	7.40							
5	晴	5.0	8.4	0.4	7.39							
6	雨	5.0	8.4	0.5	7.39							
7	晴	7.0	8.5	0.7	7.34							
8	晴	4.0	8.1	0.7	7.38							
9	晴	4.8	7.6	0.8	7.41	16.9	20.2	44	3.4	<0.03	<0.02	
10	晴	1.1	7.5	0.7	7.42							
11	晴	3.0	7.3	0.6	7.43							
12	曇	4.0	7.3	0.6	7.40							
13	晴	5.0	7.3	0.5	7.39							
14	晴	6.0	7.3	0.6	7.40							
15	曇	6.5	7.5	0.6	7.39							
16	晴	3.9	7.4	0.5	7.39							
17	晴	5.0	7.4	0.6	7.38							
18	曇	2.5	7.3	0.8	7.39							
19	曇	5.0	7.5	0.9	7.39							
20	雨	8.0	7.5	0.8	7.37							
21	晴	7.9	7.9	0.8	7.39							
22	晴	7.5	8.1	0.8	7.38							
23	曇	6.0	8.4	0.8	7.39	14.0	15.6	38	3.6	<0.03	<0.02	
24	晴	7.0	8.3	1.0	7.39							
25	晴	6.5	8.1	0.9	7.40							
26	晴	7.2	7.9	0.9	7.40							
27	曇	6.2	7.9	1.0	7.40							
28	晴	6.0	7.9	1.0	7.37							
29	晴	6.0	7.7	0.8	7.40							
30	晴	4.0	7.5	0.9	7.40							
31	晴	4.5	7.4	1.1	7.39							
平均		5.5	7.8	0.7	7.39	15.4	17.9	41	3.5	<0.03	<0.02	
最高		8.2	8.5	1.1	7.45	16.9	20.2	44	3.6	<0.03	<0.02	
最低		1.1	7.3	0.4	7.34	14.0	15.6	38	3.4	<0.03	<0.02	

令和 7年 1月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	5.8	8.6	0.3	7.50							
2	晴	8.1	8.5	0.4	7.46							
3	晴	8.2	8.4	0.4	7.43							
4	晴	5.0	8.6	0.4	7.42							
5	晴	5.0	8.5	0.4	7.41							
6	雨	5.0	8.5	0.4	7.41							
7	晴	7.0	8.5	0.4	7.38							
8	晴	4.0	8.3	0.5	7.37							
9	晴	4.8	7.9	0.6	7.39	15.4	17.6	43	3.5	<0.03	<0.02	
10	晴	1.1	7.6	0.6	7.41							
11	晴	3.0	7.3	0.5	7.44							
12	曇	4.0	7.3	0.5	7.43							
13	晴	5.0	7.3	0.5	7.42							
14	晴	6.0	7.3	0.5	7.42							
15	曇	6.5	7.4	0.4	7.41							
16	晴	3.9	7.4	0.4	7.40							
17	晴	5.0	7.4	0.4	7.40							
18	曇	2.5	7.2	0.5	7.41							
19	曇	5.0	7.3	0.6	7.41							
20	雨	8.0	7.5	0.6	7.40							
21	晴	7.9	7.7	0.7	7.40							
22	晴	7.5	7.8	0.6	7.41							
23	曇	6.0	8.1	0.5	7.40	13.9	15.5	36	3.6	<0.03	<0.02	
24	晴	7.0	8.3	0.6	7.40							
25	晴	6.5	8.2	0.7	7.41							
26	晴	7.2	7.9	0.7	7.41							
27	曇	6.2	7.9	0.7	7.41							
28	晴	6.0	8.0	0.8	7.39							
29	晴	6.0	7.9	0.8	7.40							
30	晴	4.0	7.7	0.7	7.41							
31	晴	4.5	7.5	0.7	7.41							
平均		5.5	7.9	0.5	7.41	14.6	16.6	40	3.6	<0.03	<0.02	
最高		8.2	8.6	0.8	7.50	15.4	17.6	43	3.6	<0.03	<0.02	
最低		1.1	7.2	0.3	7.37	13.9	15.5	36	3.5	<0.03	<0.02	