

令和 7年 2月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	6.0	7.4	0.8	7.41							
2	雨	5.9	7.4	0.8	7.40							
3	曇	6.4	7.5	0.8	7.38							
4	晴	4.0	7.8	1.0	7.39							
5	晴	2.0	7.8	0.8	7.41							
6	晴	2.4	7.6	0.6	7.42	12.9	14.8	38	2.8	0.03	<0.02	
7	晴	3.1	7.2	0.8	7.44							
8	雨	-2.0	6.8	0.9	7.42							
9	晴	2.6	6.3	0.9	7.42							
10	晴	4.0	6.2	0.8	7.43							
11	晴	4.5	6.3	1.0	7.43							
12	晴	6.0	6.3	0.8	7.44							
13	晴	7.2	6.6	0.6	7.41							
14	晴	7.0	6.6	0.5	7.42							
15	晴	10.0	6.8	0.5	7.42							
16	晴	7.0	7.2	0.5	7.42							
17	晴	9.3	7.6	0.7	7.43							
18	晴	2.8	7.5	0.7	7.49							
19	晴	3.0	7.5	0.7	7.46							
20	晴	2.2	7.4	0.6	7.47	14.0	15.1	32	3.2	<0.03	<0.02	
21	曇	1.0	7.1	0.6	7.47							
22	晴	5.1	6.8	0.6	7.52							
23	晴	1.5	6.5	0.6	7.57							
24	晴	2.2	6.4	0.6	7.58							
25	晴	7.0	6.3	0.6	7.58							
26	晴	8.1	6.5	0.6	7.58							
27	晴	10.1	6.7	0.6	7.59							
28	曇	10.0	7.0	0.6	7.59							
平均		4.9	7.0	0.7	7.46	13.4	15.0	35	3.0	<0.03	<0.02	
最高		10.1	7.8	1.0	7.59	14.0	15.1	38	3.2	0.03	<0.02	
最低		-2.0	6.2	0.5	7.38	12.9	14.8	32	2.8	<0.03	<0.02	