

令和 7年 3月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	11.5	7.0	0.8	7.58							
2	曇	14.3	7.4	0.8	7.56							
3	雨	11.1	7.8	0.8	7.58							
4	雨	3.9	7.9	0.8	7.52							
5	曇	9.5	8.0	0.7	7.41							
6	晴	8.0	8.5	0.7	7.41	20.0	23.0	36	3.5	0.07	<0.02	
7	晴	6.2	8.8	0.9	7.56							
8	雨	3.8	8.4	0.9	7.55							
9	晴	8.5	8.5	1.0	7.56							
10	晴	10.3	9.0	1.0	7.58							
11	雨	8.8	8.8	1.0	7.56							
12	曇	10.5	9.1	0.8	7.53							
13	晴	13.5	9.6	0.6	7.42	18.7	22.1	55	4.5	0.13	<0.02	
14	晴	12.6	10.0	1.0	7.53							
15	曇	9.5	10.1	1.1	7.58							
16	雨	8.0	9.8	1.2	7.58							
17	晴	8.2	10.1	0.7	7.59							
18	晴	6.8	9.9	0.7	7.61							
19	晴	6.0	9.7	0.7	7.67							
20	晴	6.1	9.5	0.8	7.69							
21	晴	10.6	9.4	0.9	7.68							
22	晴	14.9	9.5	0.8	7.66							
23	晴	16.5	9.8	0.7	7.66							
24	晴	16.3	10.2	0.7	7.68							
25	晴	18.7	10.7	0.6	7.71							
26	晴	19.8	11.4	0.6	7.71							
27	曇	17.1	12.1	0.7	7.72							
28	曇	18.4	12.4	0.7	7.67							
29	曇	8.2	12.0	5.7	7.37							
30	晴	11.8	12.8	2.7	7.34							
31												
平均		11.0	9.6	1.0	7.58	19.4	22.6	46	4.0	0.10	<0.02	
最高		19.8	12.8	5.7	7.72	20.0	23.0	55	4.5	0.13	<0.02	
最低		3.8	7.0	0.6	7.34	18.7	22.1	36	3.5	0.07	<0.02	

令和 7年 3月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	11.5	7.2	0.6	7.56							
2	曇	14.3	7.6	0.6	7.57							
3	雨	11.1	8.1	0.6	7.56							
4	雨	3.9	8.2	0.6	7.54							
5	曇	9.5	8.1	0.7	7.43							
6	晴	8.0	8.2	0.6	7.45	19.7	22.5	31	3.3	0.06	<0.02	
7	晴	6.2	8.4	0.6	7.53							
8	雨	3.8	8.5	0.7	7.55							
9	晴	8.5	8.5	0.7	7.55							
10	晴	10.3	8.7	0.7	7.57							
11	雨	8.8	9.1	0.7	7.56							
12	曇	10.5	9.2	0.7	7.53							
13	晴	13.5	9.4	0.5	7.42	18.7	21.5	54	4.6	0.05	<0.02	
14	晴	12.6	9.7	0.6	7.51							
15	曇	9.5	9.9	0.7	7.53							
16	雨	8.0	9.8	0.8	7.52							
17	晴	8.2	9.9	0.8	7.55							
18	晴	6.8	9.9	0.6	7.56							
19	晴	6.0	9.7	0.5	7.58							
20	晴	6.1	9.5	0.5	7.63							
21	晴	10.6	9.5	0.5	7.65							
22	晴	14.9	9.6	0.6	7.63							
23	晴	16.5	9.9	0.5	7.62							
24	晴	16.3	10.1	0.5	7.63							
25	晴	18.7	10.6	0.5	7.63							
26	晴	19.8	11.2	0.4	7.65							
27	曇	17.1	11.7	0.5	7.67							
28	曇	18.4	12.3	0.5	7.63							
29	曇	8.2	12.6	0.7	7.67							
30	晴	11.8	12.2	1.6	7.55							
31												
平均		11.0	9.6	0.6	7.57	19.2	22.0	42	4.0	0.06	<0.02	
最高		19.8	12.6	1.6	7.67	19.7	22.5	54	4.6	0.06	<0.02	
最低		3.8	7.2	0.4	7.42	18.7	21.5	31	3.3	0.05	<0.02	