

令和 7年 11月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	14.8	16.3	4.3	7.25							
2	晴	15.0	16.1	2.1	7.27							
3	晴	13.5	15.7	4.0	7.16							
4	晴	15.1	15.6	3.0	7.22							
5	曇	14.3	15.1	1.9	7.23							
6	晴	18.1	15.1	0.9	7.26	17.0	18.4	44	3.1	0.05	<0.02	
7	晴	16.6	15.1	0.7	7.36							
8	晴	14.8	15.1	0.5	7.48							
9	雨	16.0	15.0	0.5	7.62							
10	晴	16.9	15.1	0.4	7.46							
11	晴	13.7	15.1	0.4	7.47							
12	曇	10.0	14.6	0.4	7.46							
13	曇	14.0	14.4	0.4	7.52							
14	晴	16.5	14.4	0.4	7.47							
15	晴	16.4	14.3	0.4	7.46							
16	晴	16.0	14.1	0.4	7.48							
17	晴	16.1	14.1	0.4	7.53							
18	晴	13.9	14.0	0.4	7.54							
19	晴	8.5	13.8	0.4	7.52							
20	晴	12.0	13.7	0.4	7.55	20.0	21.7	45	4.3	0.08	<0.02	
21	晴	13.9	13.5	0.3	7.52							
22	晴	12.4	12.9	0.3	7.47							
23	晴	12.0	12.7	0.3	7.49							
24	晴	14.0	12.5	0.3	7.48							
25	曇	12.0	12.4	0.4	7.47							
26	晴	10.9	12.4	0.4	7.42							
27	晴	10.5	12.4	0.3	7.47							
28	晴	13.9	12.5	0.4	7.49							
29	晴	10.2	12.5	0.4	7.45							
30	晴	12.1	12.4	0.4	7.42							
平均		13.8	14.1	0.9	7.43	18.5	20.0	44	3.7	0.06	<0.02	
最高		18.1	16.3	4.3	7.62	20.0	21.7	45	4.3	0.08	<0.02	
最低		8.5	12.4	0.3	7.16	17.0	18.4	44	3.1	0.05	<0.02	

令和 7年 11月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	14.8	17.4	0.4	7.30							
2	晴	15.0	16.9	1.3	7.28							
3	晴	13.5	16.4	1.3	7.19							
4	晴	15.1	16.0	2.9	7.15							
5	曇	14.3	16.0	2.3	7.15							
6	晴	18.1	15.7	1.1	7.25	16.0	17.1	44	2.6	0.05	<0.02	
7	晴	16.6	15.7	1.2	7.20							
8	晴	14.8	15.6	0.7	7.27							
9	雨	16.0	15.6	0.6	7.33							
10	晴	16.9	15.5	0.5	7.37							
11	晴	13.7	15.4	0.4	7.35							
12	曇	10.0	15.0	0.4	7.43							
13	曇	14.0	15.0	0.4	7.43							
14	晴	16.5	14.8	0.4	7.44							
15	晴	16.4	14.8	0.4	7.43							
16	晴	16.0	14.8	0.4	7.40							
17	晴	16.1	14.7	0.4	7.41							
18	晴	13.9	14.7	0.4	7.43							
19	晴	8.5	14.2	0.4	7.44							
20	晴	12.0	13.9	0.3	7.49	20.2	22.3	42	4.4	0.07	<0.02	
21	晴	13.9	13.8	0.3	7.48							
22	晴	12.4	13.7	0.4	7.40							
23	晴	12.0	13.5	0.3	7.38							
24	晴	14.0	13.3	0.3	7.47							
25	曇	12.0	13.2	0.3	7.43							
26	晴	10.9	12.8	0.3	7.43							
27	晴	10.5	12.8	0.3	7.48							
28	晴	13.9	12.9	0.3	7.46							
29	晴	10.2	12.8	0.3	7.48							
30	晴	12.1	12.6	0.3	7.47							
平均		13.8	14.7	0.6	7.37	18.1	19.7	43	3.5	0.06	<0.02	
最高		18.1	17.4	2.9	7.49	20.2	22.3	44	4.4	0.07	<0.02	
最低		8.5	12.6	0.3	7.15	16.0	17.1	42	2.6	0.05	<0.02	