

令和 8年 1月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	4.5	8.7	0.4	7.53							
2	晴	3.0	8.5	0.4	7.53							
3	晴	3.5	8.4	0.5	7.55							
4	晴	5.1	8.1	0.5	7.54							
5	曇	5.7	7.9	0.5	7.52							
6	曇	5.0	7.6	0.6	7.58							
7	曇	4.0	7.3	0.6	7.58							
8	晴	6.2	7.1	0.6	7.60	19.9	22.8	54	4.7	0.10	<0.02	
9	晴	2.1	7.0	0.5	7.64							
10	晴	4.8	7.0	0.5	7.64							
11	晴	7.0	7.0	0.4	7.64							
12	晴	2.3	6.7	0.4	7.68							
13	晴	5.5	6.4	0.4	7.70							
14	晴	4.5	6.4	0.4	7.70							
15	晴	5.9	6.5	0.5	7.71							
16	晴	10.2	6.4	0.5	7.69							
17	晴	8.4	6.6	0.5	7.71							
18	晴	7.0	6.8	0.4	7.71							
19	晴	7.9	6.9	0.5	7.71							
20	晴	9.1	7.3	0.5	7.74							
21	晴	2.0	7.2	0.5	7.73							
22	晴	1.3	6.7	0.4	7.81	24.0	27.2	46	5.0	0.06	<0.02	
23	晴	1.9	6.4	0.4	7.78							
24	晴	5.0	6.4	0.4	7.75							
25	晴	2.0	6.3	0.4	7.73							
26	晴	0.5	6.1	0.4	7.71							
27	晴	4.9	5.7	0.4	7.72							
28	晴	5.0	5.7	0.4	7.79							
29	晴	4.6	5.8	0.5	7.77							
30	晴	2.2	5.8	0.5	7.80							
31	晴	3.5	6.0	0.5	7.79							
平均		4.7	6.9	0.5	7.68	22.0	25.0	50	4.8	0.08	<0.02	
最高		10.2	8.7	0.6	7.81	24.0	27.2	54	5.0	0.10	<0.02	
最低		0.5	5.7	0.4	7.52	19.9	22.8	46	4.7	0.06	<0.02	

令和 8年 1月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	4.5	9.1	0.3	7.56							
2	晴	3.0	8.7	0.3	7.56							
3	晴	3.5	8.3	0.4	7.58							
4	晴	5.1	8.2	0.4	7.59							
5	曇	5.7	8.1	0.4	7.58							
6	曇	5.0	7.9	0.4	7.57							
7	曇	4.0	7.5	0.4	7.59							
8	晴	6.2	7.4	0.5	7.59	19.8	22.7	54	4.6	0.09	<0.02	
9	晴	2.1	7.1	0.5	7.61							
10	晴	4.8	7.1	0.5	7.64							
11	晴	7.0	7.3	0.4	7.64							
12	晴	2.3	6.9	0.4	7.67							
13	晴	5.5	6.8	0.3	7.70							
14	晴	4.5	6.8	0.4	7.70							
15	晴	5.9	6.7	0.4	7.71							
16	晴	10.2	6.8	0.4	7.71							
17	晴	8.4	6.9	0.4	7.71							
18	晴	7.0	7.0	0.5	7.72							
19	晴	7.9	7.2	0.4	7.71							
20	晴	9.1	7.5	0.4	7.70							
21	晴	2.0	7.3	0.4	7.73							
22	晴	1.3	7.2	0.4	7.73	25.0	27.8	52	5.1	0.05	<0.02	
23	晴	1.9	6.9	0.3	7.75							
24	晴	5.0	6.7	0.3	7.73							
25	晴	2.0	6.6	0.3	7.75							
26	晴	0.5	6.4	0.3	7.75							
27	晴	4.9	6.2	0.3	7.74							
28	晴	5.0	6.2	0.3	7.75							
29	晴	4.6	6.1	0.4	7.77							
30	晴	2.2	6.0	0.4	7.75							
31	晴	3.5	6.2	0.4	7.74							
平均		4.7	7.1	0.4	7.68	22.4	25.2	53	4.8	0.07	<0.02	
最高		10.2	9.1	0.5	7.77	25.0	27.8	54	5.1	0.09	<0.02	
最低		0.5	6.0	0.3	7.56	19.8	22.7	52	4.6	0.05	<0.02	