

令和 8年 8月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	原 水 水質試験結果（沈砂池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	32.5	25.5	3.0	7.75							
2	晴	35.0	23.5	2.2	7.34							
3	晴	29.6	23.4	1.6	7.26							
4	曇	26.0	22.4	1.5	7.23							
5	晴	29.5	21.8	2.4	7.15							
6	晴	31.9	22.1	1.4	7.14	14.2	15.8	52	2.2	0.05	<0.02	
7	晴	30.0	22.3	1.3	7.15							
8	晴	29.0	22.6	1.2	7.14							
9	晴	30.0	21.7	1.2	7.14							
10	晴	29.8	21.1	1.2	7.14							
11	曇	24.8	21.0	1.2	7.13							
12	曇	24.0	21.3	1.2	7.16							
13	晴	25.5	20.4	1.2	7.15							
14	晴	28.2	20.7	1.2	7.22							
15	曇	27.5	21.6	1.4	7.24							
16	晴	27.5	21.1	1.2	7.26							
17	晴	27.9	20.4	1.0	7.26							
18	晴	28.5	20.3	1.2	7.27							
19	晴	29.0	20.3	1.2	7.27							
20	晴	28.2	20.1	1.2	7.26	14.6	15.8	32	2.3	0.09	<0.02	
21	晴	30.5	19.9	1.2	7.28							
22	晴	30.0	19.9	1.2	7.14							
23	晴	30.0	20.1	1.2	7.16							
24	晴	32.0	19.7	1.1	7.13							
25	曇	30.5	19.4	1.1	7.14							
26	晴	32.5	21.7	1.1	7.52							
27	晴	32.5	22.2	1.2	7.54							
28	晴	25.5	22.2	1.0	7.55							
29	曇	27.0	22.5	0.9	7.58							
30	晴	30.0	22.1	0.9	7.59							
31	曇	27.9	22.2	0.9	7.63							
平均		29.1	21.5	1.3	7.29	14.4	15.8	42	2.2	0.07	<0.02	
最高		35.0	25.5	3.0	7.75	14.6	15.8	52	2.3	0.09	<0.02	
最低		24.0	19.4	0.9	7.13	14.2	15.8	32	2.2	0.05	<0.02	

令和 8年 8月分

湖西工業用水道水質試験結果報告書（梅田浄水場）

採水時間 9:00

日	天候	気温 ℃	浄 水 水質試験結果（配水池）									備考
			水温 ℃	濁度 度	p H	アルカリ 度 mg/L	硬度 mg/L	蒸 発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	32.5	25.1	1.4	7.68							
2	晴	35.0	24.8	1.6	7.63							
3	晴	29.6	24.5	1.4	7.36							
4	曇	26.0	24.0	1.2	7.28							
5	晴	29.5	23.3	0.9	7.25							
6	晴	31.9	23.4	1.0	7.22	14.6	15.9	34	2.2	0.06	<0.02	
7	晴	30.0	23.5	0.8	7.23							
8	晴	29.0	23.9	0.7	7.12							
9	晴	30.0	23.2	0.7	7.23							
10	晴	29.8	22.8	0.7	7.19							
11	曇	24.8	22.0	0.7	7.15							
12	曇	24.0	22.3	0.8	7.21							
13	晴	25.5	22.0	0.7	7.22							
14	晴	28.2	21.9	0.7	7.23							
15	曇	27.5	22.7	0.8	7.29							
16	晴	27.5	22.8	0.8	7.35							
17	晴	27.9	22.0	0.7	7.33							
18	晴	28.5	21.9	0.8	7.34							
19	晴	29.0	21.8	0.9	7.35							
20	晴	28.2	21.9	0.9	7.36	14.4	15.4	34	2.1	0.07	<0.02	
21	晴	30.5	21.7	0.8	7.36							
22	晴	30.0	21.9	0.9	7.31							
23	晴	30.0	22.3	0.9	7.29							
24	晴	32.0	22.3	0.8	7.30							
25	曇	30.5	21.9	0.8	7.27							
26	晴	32.5	22.3	0.7	7.42							
27	晴	32.5	23.7	0.7	7.61							
28	晴	25.5	23.9	0.7	7.65							
29	曇	27.0	23.9	0.7	7.67							
30	晴	30.0	23.4	0.7	7.68							
31	曇	27.9	23.6	0.6	7.74							
平均		29.1	22.9	0.9	7.37	14.5	15.6	34	2.2	0.06	<0.02	
最高		35.0	25.1	1.6	7.74	14.6	15.9	34	2.2	0.07	<0.02	
最低		24.0	21.7	0.6	7.12	14.4	15.4	34	2.1	0.06	<0.02	