

令和2年6月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (滝戸沈砂池 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	全硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	22.5	14.4	0.7	7.55							
2	晴	22.2	14.4	0.5	7.47							
3	晴	24.5	14.8	0.5	7.57	40.0	49.0	133	8.2	0.04	<0.02	
4	晴	25.2	14.8	0.7	7.57							
5	晴	28.7	15.0	1.1	7.55							
6	晴	27.5	15.0	0.5	7.52							
7	晴	25.4	15.0	1.0	7.58							
8	晴	27.0	15.0	0.7	7.59							
9	曇	27.3	15.0	0.7	7.53							
10	晴	26.5	15.0	0.6	7.53							
11	雨	23.3	15.5	2.6	7.45							
12	曇	24.0	15.0	1.5	7.52							
13	雨	23.1	15.0	0.7	7.44							
14	曇	23.2	15.0	1.0	7.50							
15	晴	27.8	14.8	0.7	7.49							
16	曇	24.5	14.8	0.6	7.54							
17	晴	29.5	15.5	4.9	7.74							
18	曇	23.5	15.2	1.1	7.71	39.0	27.0	135	9.4	<0.01	<0.02	
19	雨	18.0	14.7	2.6	7.48							
20	晴	25.5	14.5	0.7	7.62							
21	晴	28.5	15.0	1.3	7.55							
22	雨	19.1	14.3	0.6	7.53							
23	曇	25.4	14.5	0.7	7.57							
24	晴	29.0	15.0	0.5	7.62							
25	雨	23.0	15.0	1.0	7.51							
26	曇	24.8	15.0	0.6	7.52							
27	曇	26.5	14.9	0.6	7.59							
28	雨	21.2	15.5	1.6	7.54							
29	晴	26.6	15.0	1.1	7.38							
30	曇	25.0	14.8	0.5	7.48							
平均		24.9	14.9	1.1	7.54	39.5	38.0	134	8.8	0.02	<0.02	
最高		29.5	15.5	4.9	7.74	40.0	49.0	135	9.4	0.04	<0.02	
最低		18.0	14.3	0.5	7.38	39.0	27.0	133	8.2	<0.01	<0.02	