

令和2年7月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (滝戸沈砂池 (原水))									備考
			水温 °C	濁度 度	pH	酸消費量 mg/l	全硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	雨	23.2	17.0	33.4	7.47							
2	晴	25.0	15.5	7.0	7.59	32.0	34.0	107	4.5	0.36	<0.02	
3	曇	24.2	15.0	2.5	7.32							
4	雨	25.2	15.8	12.1	7.43							
5	曇	24.5	15.4	4.1	7.46							
6	雨	23.0	15.3	2.9	7.43							
7	雨	24.8	17.7	589	7.73							断水
8	曇	24.8										〃
9	雨	23.6	17.0	564	7.56							〃
10	雨	24.5										〃
11	雨	27.0										〃
12	曇	27.3										〃
13	曇	23.2										〃
14	雨	22.2	14.8	3.9	7.51							
15	曇	27.0	14.0	8.0	7.59	36.0	39.0	149	5.1	0.97	0.04	
16	曇	22.7	14.6	2.8	7.54							
17	雨	21.2	14.5	2.3	7.46							
18	雨	21.0	15.0	3.4	7.51							
19	曇	24.0	14.7	1.2	7.51							
20	晴	30.0	14.7	1.2	7.56							
21	曇	26.8	14.7	1.1	7.54							
22	曇	26.0	15.0	2.0	7.45							
23	曇	25.5	14.8	1.1	7.52							
24	曇	27.5	14.7	1.0	7.60							
25	雨	24.2	17.0	20.8	7.49							
26	雨	26.0	18.0	126	7.53							断水
27	曇	26.4	18.3	485	7.65							〃
28	曇	28.0	16.8	2.1	7.46							〃
29	曇	25.0	14.4	3.8	7.53							〃
30	雨	22.0	14.8	2.0	7.52							
31	曇	24.0	14.8	2.1	7.58							
平均		24.8	15.6	72.5	7.52	34.0	36.5	128	4.8	0.67	0.02	
最高		30.0	18.3	589	7.73	36.0	39.0	149	5.1	0.97	0.04	
最低		21.0	14.0	1.0	7.32	32.0	34.0	107	4.5	0.36	<0.02	