

令和2年8月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (滝戸沈砂池 (原水))									備考	
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	全硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l		
1	晴	28.8	14.9	2.2	7.61								
2	晴	28.7	15.0	2.1	7.62								
3	晴	29.5	14.8	1.2	7.56								
4	晴	29.1	15.0	2.3	7.57								
5	晴	31.0	15.2	1.4	7.61	39.0	41.0	127	5.4	0.16	0.02		
6	晴	30.5	15.2	1.0	7.37								
7	晴	30.1	15.1	0.7	7.53								
8	晴	29.7	15.2	1.5	7.52								
9	晴	32.8	15.2	0.9	7.58								
10	晴	31.0	15.3	1.3	7.53								
11	晴	33.3	15.2	0.7	7.51								
12	晴	29.8	15.2	1.5	7.54								
13	晴	33.0	15.2	0.8	7.51								
14	晴	34.0	15.4	1.0	7.53								
15	晴	34.5	15.2	0.6	7.58								
16	晴	33.4	15.2	0.9	7.57								
17	晴	31.3	15.3	0.6	7.45								
18	晴	34.2	15.3	0.6	7.46								
19	晴	31.2	15.2	0.9	7.48	41.0	43.0	135	6.4	0.79	0.02		
20	晴	32.5	15.2	0.6	7.61								
21	晴	33.0	15.5	1.2	7.44								
22	晴	32.8	15.8	0.8	7.50								
23	曇	25.8	15.0	0.9	7.58								
24	晴	30.1	15.0	0.6	7.57								
25	晴	27.9	15.2	0.9	7.48								
26	晴	32.6	15.2	0.6	7.53								
27	曇	27.3	15.4	0.7	7.53								
28	曇	26.0	15.5	0.7	7.53								
29	晴	31.6	15.3	0.9	7.53								
30	晴	31.5	15.5	0.8	7.53								
31	晴	30.3	15.3	0.6	7.58								
平均		30.9	15.2	1.0	7.53	40.0	42.0	131	5.9	0.48	0.02		
最高		34.5	15.8	2.3	7.62	41.0	43.0	135	6.4	0.79	0.02		
最低		25.8	14.8	0.6	7.37	39.0	41.0	127	5.4	0.16	0.02		