

令和2年9月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (滝戸沈砂池 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	全硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	28.8	15.2	0.8	7.56							
2	晴	29.3	14.8	1.0	7.53	41.0	45.0	127	7.2	0.08	<0.02	
3	雨	26.2	15.3	0.9	7.43							
4	晴	29.6	15.2	1.2	7.54							
5	晴	33.2	15.2	0.9	7.62							
6	曇	30.3	16.0	2.2	7.52							
7	雨	29.0	16.0	2.1	7.54							
8	曇	29.3	17.0	22.8	7.58							断水解除による 一時的な濁度増
9	晴	31.0	15.7	3.3	7.63							
10	曇	28.4	15.4	2.6	7.54							
11	晴	31.2	15.2	2.0	7.56							
12	雨	24.5	15.1	1.5	7.55							
13	曇	28.0	15.0	1.2	7.55							
14	晴	27.6	15.0	1.8	7.53							
15	晴	29.0	14.8	1.2	7.55							
16	曇	24.2	14.8	0.7	7.56	39.0	45.0	107	6.1	0.08	<0.02	
17	曇	26.8	14.9	1.0	7.54							
18	晴	27.1	15.7	1.0	7.49							
19	晴	27.3	15.2	1.1	7.51							
20	曇	23.0	14.8	0.6	7.58							
21	曇	22.8	14.8	0.7	7.57							
22	晴	26.1	14.2	0.7	7.57							
23	曇	22.5	14.5	0.5	7.60							
24	曇	24.7	14.8	0.7	7.62							
25	曇	24.5	15.0	0.7	7.49							
26	雨	20.6	14.8	0.7	7.47							
27	曇	20.0	14.5	0.5	7.56							
28	晴	25.5	14.5	1.8	7.49							
29	晴	23.2	14.2	0.6	7.51							
30	晴	24.0	13.8	0.5	7.60							
平均		26.6	15.0	1.9	7.55	40.0	45.0	117	6.7	0.08	<0.02	
最高		33.2	17.0	22.8	7.63	41.0	45.0	127	7.2	0.08	<0.02	
最低		20.0	13.8	0.5	7.43	39.0	45.0	107	6.1	0.08	<0.02	