

令和3年1月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (滝戸沈砂池 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	全硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	8.0	10.5	0.2	7.66							
2	晴	9.7	10.4	0.2	7.62							
3	晴	6.8	10.8	0.2	7.62							
4	晴	8.1	11.2	0.2	7.62							
5	曇	6.5	10.8	0.2	7.64							
6	晴	9.5	11.2	0.3	7.59							
7	晴	8.8	10.7	0.4	7.52	41.0	45.0	109	6.1	0.03	<0.02	
8	晴	7.2	10.0	0.2	7.64							
9	晴	4.7	10.0	0.1	7.59							
10	晴	7.6	9.6	0.2	7.56							
11	晴	4.5	9.8	0.2	7.65							
12	曇	5.0	13.2	0.5	7.71							
13	晴	10.6	13.5	0.2	7.74							
14	晴	8.7	14.8	0.0	7.64							
15	晴	11.0	14.7	0.2	7.78							
16	晴	13.7	14.9	0.3	7.71							
17	曇	11.8	15.0	0.3	7.74							
18	晴	8.8	15.0	0.2	7.77							
19	晴	8.8	15.0	0.1	7.68	91.0	117.0	210	6.8	0.06	0.05	
20	晴	4.1	15.0	0.1	7.78							
21	晴	11.5	15.0	0.2	7.64							
22	晴	13.5	15.0	0.2	7.80							
23	雨	10.3	15.2	0.2	7.66							
24	雨	7.2	15.0	0.3	7.72							
25	晴	10.8	15.2	0.1	7.78							
26	晴	9.2	15.2	0.2	7.80							
27	曇	10.3	15.4	0.2	7.68							
28	曇	10.0	15.2	0.2	7.73							
29	晴	10.5	15.0	0.2	7.72							
30	晴	10.0	15.0	0.2	7.80							
31	晴	9.5	15.4	0.1	7.70							
平均		8.9	13.3	0.2	7.69	66.0	81.0	160	6.5	0.05	0.03	
最高		13.7	15.4	0.5	7.80	91.0	117.0	210	6.8	0.06	0.05	
最低		4.1	9.6	0.0	7.52	41.0	45.0	109	6.1	0.03	<0.02	