

令和3年6月分

富士川工業用水道 水質試験結果報告書（滝戸沈砂池）

採水時間 9:00

日	天候	気温 °C	水質試験結果（滝戸沈砂池：原水）									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	25.3	14.5	0.6	7.64							
2	晴	24.2	14.3	0.6	7.54	40.2	42.7	107	9.2	0.04	<0.02	
3	晴	24.3	14.3	0.5	7.58							
4	雨	23.0	14.5	1.7	7.57							
5	晴	26.3	15.1	1.7	7.61							
6	曇	21.7	14.3	0.8	7.55							
7	曇	22.1	14.5	0.6	7.56							
8	晴	28.2	14.2	0.8	7.64							
9	晴	30.5	14.8	0.6	7.65							
10	晴	28.3	14.3	0.7	7.63							
11	晴	27.1	14.5	0.6	7.57							
12	曇	24.0	14.5	0.6	7.57							
13	曇	25.8	14.9	1.0	7.55							
14	雨	22.2	14.5	1.2	7.53							
15	晴	26.5	14.5	0.9	7.60							
16	曇	24.0	14.8	0.8	7.61	40.6	33.3	126	8.4	0.03	<0.02	
17	晴	25.4	14.5	0.6	7.56							
18	晴	24.8	14.3	0.5	7.55							
19	雨	20.5	14.8	0.8	7.56							
20	晴	26.0	14.8	0.5	7.64							
21	晴	25.8	14.7	0.7	7.63							
22	晴	25.0	14.5	0.7	7.58							
23	曇	23.8	14.8	0.7	7.60							
24	晴	26.3	14.9	0.7	7.58							
25	曇	24.7	14.7	0.6	7.55							
26	晴	28.3	14.8	0.5	7.56							
27	曇	25.5	14.9	0.6	7.58							
28	曇	26.8	14.7	0.6	7.50							
29	雨	21.8	15.0	0.9	7.51							
30	曇	23.2	15.0	0.6	7.54							
平均		25.0	14.6	0.8	7.58	40.4	38.0	117	8.8	0.04	<0.02	
最高		30.5	15.1	1.7	7.65	40.6	42.7	126	9.2	0.04	<0.02	
最低		20.5	14.2	0.5	7.50	40.2	33.3	107	8.4	0.03	<0.02	