

令和3年10月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考	
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l		
1	雨	20.5	15.0	1.0	7.57								
2	晴	27.1	14.6	0.6	7.56								
3	晴	27.5	14.2	0.6	7.58								
4	晴	28.1	14.5	0.6	7.51								
5	晴	28.2	14.5	0.9	7.51	45.1	37.9	130	7.1	0.05	<0.02		
6	晴	27.2	14.4	0.8	7.57								
7	晴	27.0	14.8	0.5	7.60								
8	晴	28.8	15.0	0.6	7.58								
9	晴	28.0	14.8	0.6	7.58								
10	曇	21.7	14.7	0.5	7.55								
11	晴	26.3	14.7	0.6	7.53								
12	晴	27.0	14.9	1.3	7.60								
13	曇	20.6	14.6	0.4	7.56								
14	曇	19.8	14.5	0.5	7.52								
15	晴	27.0	14.2	0.5	7.62								
16	雨	22.5	14.5	0.5	7.56								
17	雨	19.0	14.5	0.5	7.56								
18	晴	15.8	13.5	0.3	7.55								
19	雨	13.0	13.2	0.5	7.58	42.7	40.4	124	7.1	0.06	<0.02		
20	晴	22.0	14.0	0.6	7.63								
21	晴	18.0	12.7	0.4	7.55								
22	曇	13.8	13.4	0.3	7.46								
23	晴	18.2	13.1	0.3	7.47								
24	晴	17.4	12.7	0.4	7.55								
25	曇	19.4	14.0	0.6	7.62								
26	晴	18.5	13.2	0.4	7.53								
27	曇	18.0	13.5	0.4	7.61								
28	晴	22.0	13.7	0.3	7.57								
29	晴	22.0	13.0	0.5	7.62								
30	晴	20.5	13.0	0.4	7.62								
31	曇	17.5	13.5	0.4	7.59								
平均		22.0	14.0	0.5	7.56	43.9	39.2	127	7.1	0.06	<0.02		
最高		28.8	15.0	1.3	7.63	45.1	40.4	130	7.1	0.06	<0.02		
最低		13.0	12.7	0.3	7.46	42.7	37.9	124	7.1	0.05	<0.02		