

令和3年12月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	20.0	13.2	15.3	7.55							
2	晴	15.5	11.0	0.7	7.61							
3	晴	15.2	11.3	0.5	7.55							
4	晴	13.0	11.1	0.3	7.60							
5	曇	9.3	11.3	0.3	7.57							
6	曇	10.2	12.0	0.3	7.62	43.3	46.9	119	6.8	0.03	<0.02	
7	曇	13.5	12.3	0.3	7.59							
8	雨	9.8	12.3	0.6	7.55							
9	晴	13.7	12.0	0.5	7.55							
10	曇	12.0	11.8	0.2	7.60							
11	晴	15.0	11.5	0.3	7.70							
12	晴	15.0	11.5	0.5	7.71							
13	晴	15.1	11.9	0.3	7.55							
14	曇	7.2	11.5	0.3	7.64							
15	晴	13.0	11.5	0.2	7.62							
16	晴	12.7	11.2	0.4	7.62							
17	曇	10.0	12.0	1.1	7.60							
18	晴	10.2	11.0	0.2	7.70							
19	晴	8.5	10.3	0.2	7.64							
20	晴	12.0	10.8	0.3	7.74							
21	晴	9.8	12.0	0.2	7.59	41.4	42.4	115	9.6	0.02	<0.02	
22	晴	14.0	11.0	0.3	7.60							
23	晴	10.9	11.5	0.3	7.58							
24	晴	11.5	11.3	0.3	7.62							
25	曇	13.2	12.1	0.3	7.61							
26	晴	10.8	11.5	0.2	7.69							
27	晴	5.2	10.5	0.1	7.67							
28	晴	5.0	10.7	0.4	7.66							
29	晴	8.7	11.0	0.2	7.62							
30	晴	14.0	11.0	0.2	7.71							
31	晴	10.0	11.0	0.2	7.62							
平均		11.7	11.5	0.8	7.62	42.4	44.7	117	8.2	0.03	<0.02	
最高		20.0	13.2	15.3	7.74	43.3	46.9	119	9.6	0.03	<0.02	
最低		5.0	10.3	0.1	7.55	41.4	42.4	115	6.8	0.02	<0.02	