

令和4年1月分

富士川工業用水道 水質試験結果報告書 (滝戸沈砂池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	9.0	10.2	0.2	7.67							
2	晴	6.8	10.5	0.1	7.61							
3	晴	12.0	10.8	0.2	7.70							
4	晴	13.2	11.0	0.1	7.65							
5	晴	7.1	10.7	0.2	7.69							
6	曇	3.9	11.0	0.1	7.62							
7	晴	9.0	10.8	0.1	7.72							
8	晴	4.2	10.7	0.2	7.67							
9	晴	7.1	11.0	0.2	7.72							
10	晴	9.8	11.2	0.2	7.57							
11	曇	9.0	11.5	0.6	7.61	40.7	40.8	121	10.6	0.04	<0.02	
12	晴	10.2	11.0	0.5	7.62							
13	晴	9.4	10.7	0.2	7.58							
14	晴	9.0	10.8	0.2	7.64							
15	晴	8.4	10.3	0.3	7.67							
16	晴	10.5	10.8	0.1	7.68							
17	晴	11.0	10.8	0.2	7.68							
18	晴	7.4	10.5	0.6	7.58	41.9	40.6	121	9.9	0.27	<0.02	
19	曇	4.0	10.0	0.4	7.58							
20	晴	8.8	10.3	0.3	7.65							
21	晴	6.6	10.1	0.2	7.53							
22	晴	7.0	10.0	0.2	7.68							
23	曇	7.0	10.3	0.2	7.62							
24	曇	8.0	11.0	0.1	7.57							
25	晴	4.5	11.0	0.3	7.63							
26	曇	10.0	11.0	0.3	7.66							
27	晴	8.0	10.7	0.3	7.58							
28	晴	7.5	10.6	0.2	7.65							
29	晴	7.8	11.0	0.3	7.58							
30	曇	6.5	10.5	0.3	7.60							
31	晴	11.6	10.7	0.3	7.62							
平均		8.2	10.7	0.2	7.63	41.3	40.7	121	10.3	0.16	<0.02	
最高		13.2	11.5	0.6	7.72	41.9	40.8	121	10.6	0.27	<0.02	
最低		3.9	10.0	0.1	7.53	40.7	40.6	121	9.9	0.04	<0.02	