

令和4年4月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	7.0	12.8	2.1	7.64							
2	曇	8.7	11.6	0.8	7.71							
3	雨	6.9	11.9	0.7	7.56							
4	雨	7.0	11.0	1.6	7.58							
5	晴	17.5	11.5	1.1	7.72	41.0	34.6	112	8.3	0.04	<0.02	
6	晴	16.3	12.3	0.9	7.61							
7	晴	18.2	12.2	0.7	7.65							
8	晴	20.5	12.6	0.7	7.70							
9	晴	17.1	12.5	0.7	7.60							
10	晴	23.0	12.8	0.8	7.72							
11	晴	22.0	13.0	0.8	7.70							
12	晴	24.2	13.8	0.6	7.60							
13	晴	23.0	14.0	0.8	7.68							
14	曇	18.2	14.0	0.6	7.52							
15	雨	14.0	13.4	1.0	7.49							
16	雨	11.0	13.2	0.8	7.64							
17	雨	11.5	12.6	0.9	7.68							
18	雨	12.8	13.0	0.8	7.61							
19	曇	16.3	12.8	1.3	7.61	41.0	37.5	120	8.9	0.02	<0.02	
20	晴	19.0	13.5	1.0	7.64							
21	曇	18.0	13.0	1.0	7.68							
22	晴	22.0	13.7	8.0	7.56							
23	晴	20.5	14.0	1.1	7.59							
24	曇	20.0	14.2	1.2	7.63							
25	晴	18.5	14.9	1.5	7.75							
26	曇	19.8	14.2	1.4	7.62							
27	曇	20.1	15.0	5.6	7.55							
28	曇	18.5	14.0	1.1	7.56							
29	曇	18.2	13.3	1.0	7.52							
30	晴	15.5	12.8	2.8	7.56							
31												
平均		16.8	13.1	1.4	7.62	41.0	36.1	116	8.6	0.03	<0.02	
最高		24.2	15.0	8.0	7.75	41.0	37.5	120	8.9	0.04	<0.02	
最低		6.9	11.0	0.6	7.49	41.0	34.6	112	8.3	0.02	<0.02	