

令和4年5月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	17.0	13.0	1.1	7.64							
2	晴	18.4	12.8	1.4	7.58							
3	晴	18.0	12.2	1.2	7.73							
4	晴	18.3	12.5	1.5	7.59							
5	晴	23.2	13.4	1.1	7.58							
6	晴	20.5	13.0	1.5	7.64							
7	晴	21.0	13.8	0.8	7.72							
8	曇	22.9	14.0	1.1	7.59							
9	曇	20.2	13.7	0.8	7.51	40.8	40.5	114	8.0	0.03	<0.02	
10	晴	18.5	13.5	1.1	7.63							
11	曇	21.5	13.2	0.7	7.62							
12	曇	20.4	13.7	1.0	7.57							
13	雨	18.3	14.3	0.6	7.51							
14	曇	20.4	15.3	5.8	7.46							
15	曇	20.0	14.0	1.0	7.61							
16	雨	15.4	13.9	1.1	7.53							
17	曇	16.8	13.8	0.7	7.54	41.3	42.1	114	8.3	0.05	<0.02	
18	晴	22.0	13.2	0.7	7.67							
19	晴	24.0	13.5	0.7	7.69							
20	曇	19.3	13.9	0.8	7.60							
21	雨	18.2	14.3	0.8	7.46							
22	晴	20.2	14.0	0.8	7.55							
23	晴	23.6	14.0	0.7	7.60							
24	晴	22.3	14.2	0.8	7.56							
25	晴	18.1	14.3	0.5	7.29							
26	晴	25.0	14.2	0.8	7.68							
27	雨	18.4	15.1	9.0	7.52							
28	晴	25.0	14.5	9.1	7.68							
29	晴	27.0	14.5	3.0	7.66							
30	晴	27.5	14.2	1.7	7.72							
31	雨	19.4	14.6	2.5	7.61							
平均		20.7	13.8	1.8	7.59	41.1	41.3	114	8.2	0.04	<0.02	
最高		27.5	15.3	9.1	7.73	41.3	42.1	114	8.3	0.05	<0.02	
最低		15.4	12.2	0.5	7.29	40.8	40.5	114	8.0	0.03	<0.02	