

令和4年8月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	30.6	16.4	0.9	7.54							
2	曇	30.0	16.2	0.8	7.65	40.5	42.8	118	7.0	0.07	<0.02	
3	曇	29.5	16.0	0.9	7.55							
4	雨	26.6	16.0	0.9	7.54							
5	曇	26.2	15.7	0.7	7.59							
6	曇	23.5	15.5	1.0	7.53							
7	晴	28.8	15.5	0.7	7.56							
8	晴	30.0	16.0	0.8	7.56							
9	曇	30.5	16.0	0.8	7.57							
10	晴	31.5	16.0	0.7	7.60							
11	晴	32.7	16.2	0.7	7.59							
12	雨	26.8	17.0	2.8	7.62							
13	雨	24.8	18.8	32.2	7.54							
14	曇	26.3	17.0	7.9	7.69							
15	晴	30.8	16.9	2.5	7.68							
16	晴	32.0	16.4	2.6	7.73	48.3	39.9	114	5.1	0.16	<0.02	
17	曇	26.2	16.2	1.2	7.64							
18	雨	24.2	16.8	5.3	7.53							
19	晴	30.0	16.1	1.9	7.68							
20	晴	27.1	15.0	1.9	7.60							
21	曇	29.0	15.0	1.3	7.62							
22	晴	28.3	16.0	2.6	7.64							
23	晴	28.0	15.6	0.9	7.58							
24	晴	29.5	15.8	1.4	7.60							
25	曇	23.2	15.3	1.0	7.59							
26	曇	28.4	16.0	1.2	7.51							
27	晴	29.1	15.4	1.1	7.57							
28	雨	28.0	15.8	0.8	7.60							
29	曇	27.6	15.0	1.6	7.59							
30	晴	27.4	15.2	0.9	7.61							
31	雨	26.0	16.0	0.5	7.54							
平均		28.1	16.0	2.6	7.59	44.4	41.4	116	6.1	0.12	<0.02	
最高		32.7	18.8	32.2	7.73	48.3	42.8	118	7.0	0.16	<0.02	
最低		23.2	15.0	0.5	7.51	40.5	39.9	114	5.1	0.07	<0.02	