

令和5年4月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	11.8	12.0	0.7	7.65							
2	晴	15.3	12.2	0.8	7.71							
3	曇	10.8	12.6	0.9	7.65							
4	晴	10.1	11.8	0.7	7.68							
5	曇	12.5	12.3	0.7	7.63	40.5	37.6	119	9.5	0.03	<0.02	
6	晴	13.5	13.0	0.7	7.55							
7	晴	15.2	13.5	0.5	7.53							
8	晴	16.5	14.0	1.8	7.63							
9	晴	17.2	11.6	0.8	7.67							
10	曇	13.6	11.8	0.6	7.74							
11	晴	17.8	12.5	0.7	7.70							
12	曇	12.3	13.3	0.7	7.59							
13	雨	13.0	12.8	0.9	7.67							
14	曇	13.0	12.8	0.6	7.64							
15	晴	14.7	13.5	1.2	7.53							
16	晴	15.7	13.2	0.8	7.68							
17	晴	18.5	12.7	0.7	7.63							
18	雨	11.4	12.7	0.7	7.61	41.5	45.1	121	10.0	0.02	<0.02	
19	晴	11.0	13.5	0.9	7.54							
20	晴	14.7	13.8	0.7	7.62							
21	曇	15.2	14.2	0.7	7.58							
22	晴	21.0	14.0	0.7	7.58							
23	雨	14.7	13.0	1.1	7.65							
24	曇	18.4	13.3	1.2	7.61							
25	雨	13.2	13.6	0.8	7.56							
26	雨	12.0	12.8	6.1	7.55							
27	曇	11.5	13.0	1.3	7.62							
28	曇	12.1	13.5	0.8	7.67							
29	晴	16.2	13.5	1.0	7.63							
30	晴	16.5	14.3	10.3	7.52							
31												
平均		14.3	13.0	1.3	7.62	41.0	41.4	120	9.8	0.03	<0.02	
最高		21.0	14.3	10.3	7.74	41.5	45.1	121	10.0	0.03	<0.02	
最低		10.1	11.6	0.5	7.52	40.5	37.6	119	9.5	0.02	<0.02	