

令和5年8月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	28.4	15.2	0.8	7.52							
2	晴	30.0	16.1	2.6	7.60	44.4	43.1	120	8.1	0.08	<0.02	
3	晴	30.4	16.4	2.4	7.60							
4	晴	31.5	16.2	2.0	7.68							
5	晴	32.3	14.5	1.0	7.58							
6	晴	32.5	17.0	1.0	7.62							
7	曇	27.7	16.8	0.8	7.66							
8	晴	31.0	16.2	0.6	7.60							
9	雨	26.0	16.4	1.0	7.50							
10	晴	30.7	16.8	1.2	7.56							
11	晴	30.5	16.2	0.7	7.61							
12	晴	30.3	16.2	0.6	7.60							
13	晴	34.0	16.4	0.8	7.60							
14	曇	30.6	16.2	1.1	7.58	43.0	45.8	118	7.7	0.37	0.03	
15	曇	28.2	17.0	2.1	7.63							
16	雨	23.6	19.0	22.9	7.48							
17	晴	29.4	17.7	4.3	7.65							
18	晴	29.4	16.7	7.6	7.65							
19	曇	32.5	17.0	1.8	7.70							
20	晴	33.5	17.3	2.0	7.71							
21	晴	32.0	17.8	1.8	7.72							
22	晴	31.2	16.5	1.4	7.68							
23	雨	26.5	16.2	1.1	7.65							
24	曇	30.0	16.6	1.4	7.89							
25	晴	26.5	16.5	0.9	7.72							
26	晴	30.2	16.1	0.9	7.65							
27	晴	30.2	16.5	0.8	7.70							
28	曇	29.3	16.2	1.4	7.70							
29	晴	31.0	16.5	1.3	7.78							
30	晴	30.1	16.0	0.9	7.71							
31	晴	32.0	16.2	1.0	7.71							
平均		30.0	16.5	2.3	7.65	43.7	44.5	119	7.9	0.23	<0.02	
最高		34.0	19.0	22.9	7.89	44.4	45.8	120	8.1	0.37	0.03	
最低		23.6	14.5	0.6	7.48	43.0	43.1	118	7.7	0.08	<0.02	