

令和5年10月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	30.0	15.8	0.6	7.60							
2	晴	27.5	15.3	0.8	7.63							
3	晴	26.0	15.0	0.6	7.66	48.7	43.1	105	7.4	0.04	<0.02	
4	曇	18.1	15.1	1.3	7.54							
5	曇	22.7	15.0	0.6	7.60							
6	晴	23.5	14.0	0.9	7.63							
7	晴	21.8	14.0	0.8	7.64							
8	曇	19.3	14.3	0.7	7.55							
9	雨	14.5	14.0	0.6	7.54							
10	曇	21.1	15.0	1.8	7.62							
11	曇	21.2	14.0	0.6	7.65							
12	晴	23.2	14.3	0.9	7.61							
13	晴	23.0	14.0	0.5	7.57							
14	曇	18.0	13.8	0.5	7.71							
15	雨	14.8	14.4	0.9	7.54							
16	晴	22.0	13.8	0.9	7.63							
17	晴	21.2	14.0	0.5	7.63	43.3	35.2	116	7.7	0.05	<0.02	
18	晴	24.5	14.0	0.5	7.64							
19	晴	22.4	14.0	0.5	7.59							
20	晴	24.5	14.2	0.6	7.62							
21	晴	20.6	14.3	0.5	7.63							
22	晴	20.0	13.2	0.5	7.58							
23	晴	19.6	13.2	0.4	7.61							
24	晴	20.7	13.0	0.5	7.63							
25	晴	17.3	13.2	0.2	7.58							
26	晴	22.2	13.2	0.4	7.64							
27	晴	20.3	13.5	0.4	7.61							
28	晴	22.4	13.7	0.6	7.61							
29	曇	15.1	14.0	0.4	7.59							
30	晴	20.5	13.0	0.4	7.68							
31	曇	16.7	13.5	0.5	7.57							
平均		21.1	14.1	0.6	7.61	46.0	39.2	111	7.6	0.05	<0.02	
最高		30.0	15.8	1.8	7.71	48.7	43.1	116	7.7	0.05	<0.02	
最低		14.5	13.0	0.2	7.54	43.3	35.2	105	7.4	0.04	<0.02	