

令和6年1月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	15.3	11.7	0.5	7.91							
2	雨	5.5	11.7	0.2	7.75							
3	曇	7.2	11.2	0.0	7.82							
4	曇	11.5	12.0	0.2	7.83							
5	晴	10.3	11.2	0.3	7.90							
6	晴	12.0	11.0	0.2	7.87							
7	晴	14.7	11.3	0.3	7.89							
8	晴	9.8	10.8	0.1	8.05							
9	晴	6.8	10.2	0.3	7.83							
10	晴	10.0	10.6	0.3	7.95							
11	曇	6.0	11.2	0.2	7.86							
12	晴	6.2	10.1	0.2	7.83							
13	晴	10.3	10.5	0.3	7.83							
14	晴	8.7	10.1	0.3	7.87							
15	曇	6.0	10.5	0.3	7.81	43.0	43.5	133	7.9	<0.01	<0.02	
16	晴	5.8	10.0	0.4	7.88							
17	晴	10.0	9.8	0.4	7.91							
18	晴	10.3	10.5	0.4	7.96							
19	曇	11.0	11.5	0.4	7.88							
20	雨	7.7	11.7	0.4	7.83							
21	雨	7.5	11.0	1.7	7.83							
22	曇	9.6	11.5	0.6	7.92	41.2	44.5	135	8.3	0.06	<0.02	
23	晴	13.2	11.5	0.6	8.02							
24	晴	6.8	10.1	0.3	7.79							
25	晴	5.6	10.7	0.4	7.85							
26	晴	6.3	9.9	0.4	7.84							
27	晴	8.2	10.0	0.5	7.91							
28	曇	5.7	10.5	0.2	7.85							
29	晴	9.5	10.2	0.2	8.08							
30	晴	11.6	10.8	0.5	7.94							
31	晴	11.2	10.7	0.4	7.97							
平均		9.0	10.8	0.4	7.89	42.1	44.0	134	8.1	0.03	<0.02	
最高		15.3	12.0	1.7	8.08	43.0	44.5	135	8.3	0.06	<0.02	
最低		5.5	9.8	0.0	7.75	41.2	43.5	133	7.9	<0.01	<0.02	