

令和6年3月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	7.6	11.0	2.0	7.74							
2	晴	12.0	10.5	0.8	7.78							
3	晴	8.8	10.8	2.4	7.76							
4	晴	12.0	10.5	0.4	7.82	41.2	37.1	136	8.1	0.01	<0.02	
5	曇	8.0	11.1	0.5	7.77							
6	雨	7.2	10.3	1.6	7.81							
7	曇	6.4	11.0	0.4	7.79							
8	晴	10.2	11.0	0.3	7.82							
9	晴	17.0	10.7	0.4	7.82							
10	晴	11.2	10.1	0.4	7.86							
11	晴	10.3	10.1	0.5	7.82	41.2	37.1	118	8.0	0.03	<0.02	
12	雨	6.8	11.0	0.5	7.83							
13	晴	14.9	10.5	1.4	7.85							
14	晴	12.0	10.7	1.3	7.87							
15	晴	15.0	10.8	0.4	7.83							
16	晴	15.5	11.0	0.5	7.81							
17	晴	16.1	12.0	0.4	7.77							
18	晴	17.0	12.0	0.4	7.76							
19	晴	8.0	10.2	0.5	7.78							
20	晴	13.1	11.0	0.4	7.81							
21	晴	11.0	10.2	0.4	7.82							
22	晴	11.5	10.1	0.5	7.85							
23	雨	4.5	10.7	0.5	7.75							
24	晴	8.2	11.0	0.4	7.78							
25	雨	10.3	12.0	0.3	7.78							
26	雨	9.5	12.2	0.4	7.66							
27	晴	15.0	11.2	0.5	7.80							
28	曇	11.2	12.1	0.6	7.77							
29	雨	15.2	12.3	18.3	7.58							
30	晴	18.8	12.0	5.1	7.72							
31	晴	22.2	12.8	13.0	7.75							
平均		11.8	11.1	1.8	7.79	41.2	37.1	127	8.1	0.02	<0.02	
最高		22.2	12.8	18.3	7.87	41.2	37.1	136	8.1	0.03	<0.02	
最低		4.5	10.1	0.3	7.58	41.2	37.1	118	8.0	0.01	<0.02	