

令和6年4月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	19.2	13.2	1.0	7.72	39.8	38.2	130	5.9	0.03	<0.02	
2	晴	17.2	12.0	0.6	7.86							
3	雨	14.0	12.4	0.8	7.62							
4	雨	14.2	12.8	0.7	7.64							
5	曇	15.5	13.0	0.4	7.68							
6	晴	16.7	12.3	0.6	7.67							
7	晴	20.5	13.1	0.8	7.68							
8	曇	20.2	13.1	0.6	7.68							
9	雨	17.7	14.0	5.2	7.74							
10	晴	17.2	12.0	6.2	7.72							
11	晴	17.5	11.8	1.1	7.72							
12	曇	16.1	12.4	1.4	7.68							
13	晴	19.0	12.5	0.7	7.72							
14	晴	19.8	12.9	0.8	7.72							
15	晴	22.8	13.2	1.1	7.67	41.3	39.7	132	7.5	0.04	<0.02	
16	晴	21.3	13.3	0.8	7.69							
17	曇	20.5	13.8	0.9	7.64							
18	曇	19.1	13.9	0.9	7.61							
19	晴	24.0	13.4	1.3	7.61							
20	晴	23.0	13.1	0.9	7.60							
21	曇	22.0	14.0	0.7	7.65							
22	曇	18.5	14.0	1.0	7.62							
23	晴	19.2	14.0	0.9	7.60							
24	雨	14.5	13.8	0.7	7.59							
25	晴	14.8	14.1	0.4	7.56							
26	晴	24.0	14.0	0.5	7.64							
27	曇	17.4	14.0	0.6	7.60							
28	晴	24.7	14.0	0.9	7.55							
29	曇	22.7	14.0	1.1	7.73							
30	曇	22.0	14.5	1.1	7.60							
31												
平均		19.2	13.3	1.2	7.66	40.6	39.0	131	6.7	0.04	<0.02	
最高		24.7	14.5	6.2	7.86	41.3	39.7	132	7.5	0.04	<0.02	
最低		14.0	11.8	0.4	7.55	39.8	38.2	130	5.9	0.03	<0.02	